



SAN BERNARDINO COUNTY FIRE DEPARTMENT

OFFICE OF THE FIRE MARSHAL

COMMUNITY SAFETY DIVISION

SUBMITTAL CHECKLIST

STANDPIPE & HOSE SYSTEMS - NFPA 14

GENERAL REQUIREMENTS:

1. _____ A minimum of three sets of drawings
2. _____ Completed application
3. _____ Payment

REQUIREMENTS ON PLANS:

1. _____ Project / Building name, street address and city
2. _____ Building number and/or suite (if applicable)
3. _____ Name, address, phone number and license number of C-16 contractor
4. _____ Assessor's Parcel Number (APN)
5. _____ Scaled or fully dimensioned drawings
6. _____ Point of Compass
7. _____ Occupancy class
8. _____ Description of hazard
9. _____ Elevation diagram
10. _____ Location of fire walls and partitions
11. _____ Equipment symbol legend per NFPA 720
12. _____ Class of standpipe system
13. _____ Plot plan showing supply piping and pipe size from the water source to the building
14. _____ Building dimensions, height and location of the Fire Department Connection (FDC)
15. _____ Valve details and locations

IF WAREHOUSE, PLANS MUST INCLUDE THE FOLLOWING:

1. _____ Pressure Relieve Valve (PRV)
2. _____ Every other Fire Department access door
3. _____ Standpipe plumbed from adjoining system
4. _____ Calculations to prove 250 GPM
5. _____ Hydrant blue dot adjacent to door where standpipe is located

ADDITIONAL REQUIREMENTS:

1. _____ Three sets of hydraulic calculations with summary, detail worksheets and graph sheet
2. _____ Flow report dated within one year of submittal
3. _____ Detailed cut sheet and specification sheets for all equipment
4. _____ Previously approved Underground plans
5. _____ Previously approved new Construction plans

These are the minimum general requirements for plan check submittal. Additional requirements may be required upon review.