Rev 7/18/12

FIRE HYDRANT

This is a "Blow-Off".
This is *NOT* an approved hydrant.

This is a "Jones-Head".
This also is *NOT* an approved hydrant.

This hydrant is approved for applications requiring Fire Flow of *NOT MORE THAN* 1000 gpm. Fire Flow letter shall be submitted with application. However, it *cannot* be installed as a new hydrant

This hydrant is approved for all residential and light commercial applications. Fire Flow letter shall be submitted with application.
This type shall be installed for all new applications

For residential projects, hydrant must be within 300 feet of project driveway. Hydrant must be located on the address side of the same street the project is located on.