



Public Health
Environmental Health Services

www.SBCounty.gov

RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

FACILITY NAME MCDONALD'S 14975		DATE 4/22/2015	REINSPECTION DATE Next Routine	PERMIT EXPIRATION 12/31/2015
LOCATION 1796 E LUGONIA AV, REDLANDS, CA 92374			INSPECTOR Yvette Velasco	
MAILING ADDRESS PO BOX 13490, PALM DESERT CA 92255			IDENTIFIER: None	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN 4:48 PM	TIME OUT 5:00 PM	FACILITY ID FA0001652	RELATED ID PR0010703	PE 1622
RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED				
ACTION: 01 - NO FURTHER ACTION REQUIRED				

RETAIL FOOD PROTECTION - Public Eating PI (100-Up Seats)

16K994 Reinspection

Compliance Date: Not Specified
 Not In Compliance
 Reference - HSC

Inspector Comments: During the last routine inspection the maximum water temperature in the facility was observed at 114F at the mop sink. During the follow-up that same day (4/21/15) the maximum water in the facility was observed at 108F at the mop sink.

PIC stated that the water heater had since been repaired. Observed the maximum water in the facility at 120F at the mop and three-compartment sinks.

There is no need for additional inspections regarding the water temperature at this facility.

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME: aracely mora
 TITLE:

Total # of Images: 0