



RETAIL FOOD PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

FACILITY NAME 7-ELEVEN		DATE 9/4/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION
LOCATION 10492 CEDAR AV, BLOOMINGTON, CA 92316			INSPECTOR Robert Adams	
MAILING ADDRESS 9021 RANCHO PARK CT RANCHO CUCAMONGA, CA 91730			IDENTIFIER: None	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 126 - PLAN CHECK FIELD INSPECTION	
TIME IN 12:50 PM	TIME OUT 1:23 PM	FACILITY ID FA0007642	RELATED ID SR0067109	PE 1779
RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU				
ACTION: 03 - REINSPECTION REQUIRED				

RETAIL FOOD PLAN CHECK - PInCk FHP Minor 0-2,499 SqFt

17K994 Reinspection

Compliance Date: Not Specified

Not In Compliance

Reference - HSC

Inspector Comments: Reinspection conducted this date. All corrections except one have been made. See report for remaining corrections.

Description: Reinspection conducted at this time to determine compliance from prior inspection.

17K112 Floors - General - Requirement

Compliance Date: Not Specified

Not In Compliance

Reference - HSC - 114268

Inspector Comments: Observed sheet vinyl cove peeling from the wall. Repair or replace cove base below the three compartment sink.

Description: Floor surfaces in all areas in which food is prepared, packaged, or stored, where any utensil is washed, where refuse or garbage is stored, where janitorial facilities are located, in all toilet and handwashing areas and in employee change and storage areas shall be of an approved type that continues up the wall four (4) inches, in a seamless manner, forming a 3/8 inch minimum radius cove as an integral unit.

17K405 Structure - Walls - Behind Sinks

Compliance Date: Not Specified

Not In Compliance

Reference - CCDEH Guidelines - CCDEH

Inspector Comments: Provide FRP as prescribed below from the door frame on the right hand side of the hand sink to the door frame on the left side of the 3 compartment sink. See requirements below.

Description: The wall surfaces behind and adjacent all sinks (including Handwash and Mop sinks) shall be covered with fiberglass reinforced polyester (FRP), stainless steel, tile, or the equivalent. The approved wall cover must extend up the wall at least four (4) feet from the coved base and cover the walls behind the sink and accompanying drainboards to a minimum of eighteen (18) inches on both sides.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:

TITLE:

Total # of Images: 0