



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME BEL AIRE MOBILE ESTATES		DATE 4/17/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2015
LOCATION 13060 2ND ST, YUCAIPA, CA 92399			INSPECTOR Tia Wilson	
MAILING ADDRESS PO BOX 760, ALPINE CA 91903			IDENTIFIER: Spa	
TIME IN 5:08 PM			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT 5:20 PM			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
FACILITY ID FA0007234			ACTION: 01 - NO FURTHER ACTION REQUIRED	
RELATED ID PR0014701			PE 3623	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

96

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	8
volume (gal)	4,000
area (sq ft)	No Data
occupancy	13

36K414 Water Quality - Non-Critical - pH High/Low

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed pH measuring 7.1.
	Not In Compliance	Maintain pH between 7.2 and 8.0.
	Violation Reference - CCR - 65529	

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid concentration measuring above 100 ppm.
	Not In Compliance	Lower cyanuric acid level to less than 100 ppm.
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

Overall Inspection Comments

Measured observations:
 Temperature 102.9
 pH 7.1
 Free Chlorine 2.83
 Cyanuric Acid reading "HI" indicating concentration above 100 ppm

Signature(s) of Acknowledgement

NAME: Signature not available
 TITLE:

Total # of Images: 0