



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME VILLA GABRIEL HOA		DATE 6/23/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2015
LOCATION 8300 GABRIEL DR, RANCHO CUCAMONGA, CA 91730			INSPECTOR Shannon Johnson	
MAILING ADDRESS PO BOX 5022, UPLAND CA 91785			IDENTIFIER: Pool	
TIME IN 3:44 PM			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT 4:20 PM			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
FACILITY ID FA0004427			ACTION: 03 - REINSPECTION REQUIRED	
RELATED ID PR0015418			PE 3620	



**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**95**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$ 4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	87.0
observed flow (gpm)	45
required flow (gpm)	80
volume (gal)	29,000
area (sq ft)	940
occupancy	42

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:  
1. Meet the latest ANSI/APSP-16 performance standard  
2. Be rated for the maximum designed flow-rate of the pump  
Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K538 Enclosure – Non-Critical – Fencing/Enclosure**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed gaps greater than 4 inches between the bottom of the enclosure and the ground below near the pump enclosure, adjacent to the pool house, and near the mailboxes for the residents of this location. All gaps greater than 4 inches must be eliminated. A follow up inspection will be conducted to ensure compliance regarding this matter.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

**Violation Description:** The enclosure shall have a minimum effective perpendicular height of 5 feet. Openings, holes or gaps in the enclosure, doors and/or gates shall not allow the passage of a 4-inch (102 mm) diameter sphere. The enclosure shall be designed and constructed so that it cannot be readily climbed by small children. Chain link may be used, provided that the openings are not greater than 1 3/4 inches (44 mm) measured horizontally.

**36K552 Equipment - Flow meter provided**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed the flow meter to be reading 45 GPM. This reading should be 80 GPM.
	Not In Compliance	
	Violation Reference - CCR 24 - 3125B.3	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow and installed according to the manufacturer's written instructions with increments in the range of normal flow.

**36K554 Equipment - Pressure/Vacuum gauge requirements**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no clean start up pressure reading marking on the filter pressure gauge.
	Not In Compliance	
	Violation Reference - CCR 24 - 3125B.2	

**Violation Description:** A pressure and vacuum gauge shall be provided for each pump system. Each gauge shall have a scale range approximately 1 1/4 times the maximum anticipated working pressure or vacuum and shall be accurate within 2 percent of scale. The pressure gauge located on the filter shall be marked with the clean start up pressure reading.

**36K562 Skimmers - Pool skimming systems**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no float assembly within any of the skimmers.
	Not In Compliance	
	Violation Reference - CCR - 3136B	

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.



**Public Health**  
**Environmental Health Services**

www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>VILLA GABRIEL HOA</b>	DATE <b>6/23/2015</b>
LOCATION <b>8300 GABRIEL DR, RANCHO CUCAMONGA, CA 91730</b>	INSPECTOR <b>Shannon Johnson</b>

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K576 Maintenance – Operation/Incident records**

<b>POINTS</b>  <b>1</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed no monthly cyanuric acid reading recorded on the daily records for review.
	<b>Not In Compliance</b> Violation Reference - HSC - 65523	

**Violation Description:** The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

**Overall Inspection Comments**

A follow up inspection will be conducted on 7-21-15 to ensure that all gaps greater than 4 inches have been eliminated between the bottom of the enclosure and the ground below. Failure to achieve compliance regarding this matter by this time will result in a charged inspection to ensue.

**Signature(s) of Acknowledgement**

NSC

NAME:  
 TITLE:  
 Total # of Images: 0