



Public Health
Environmental Health Services



www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME COLTON COMMUNITY CENTER		DATE 6/25/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
LOCATION 670 COLTON AV, COLTON, CA 92324			INSPECTOR John Babalola	
MAILING ADDRESS 650 LA CADENA DR, COLTON CA 92324			IDENTIFIER: Splash Pad	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN 3:17 PM	TIME OUT 3:41 PM	FACILITY ID FA0001922	RELATED ID PR0034206	PE 3621
RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED				
ACTION: 01 - NO FURTHER ACTION REQUIRED				

RECREATIONAL HEALTH - Public Pool - Additional Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	400
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

No Violations Cited

Overall Inspection Comments

All violations from the previous inspection have been corrected. However, the floor drain in the equipment room is observed clogged. Pool of water buildup observed on the floor. Make repairs.

Signature(s) of Acknowledgement

NAME: Mario Townes
TITLE: Program Specialist

Total # of Images: 0