



Public Health
Environmental Health Services



www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME TILTON APARTMENTS		DATE 6/18/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 9/30/2015
LOCATION 32 N SAN MATEO , REDLANDS, CA 92373			INSPECTOR Yvette Velasco	
MAILING ADDRESS PO BOX 668 , MENTONE CA 92359			IDENTIFIER: Pool	
<input type="checkbox"/> FACILITY <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 008 - INSPECTION - ATTEMPTED	
TIME IN 9:12 AM	TIME OUT 9:14 AM	FACILITY ID FA0008742	RELATED ID PR0015918	PE 3620
			RESULT: 00 - NOT APPLICABLE	
			ACTION: 00 - NOT APPLICABLE	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K996 Attempted Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: A routine inspection of the pool was attempted. Observed that the lock has been changed and the key provided is no longer functional. Ensure to provide access to the pool for routine inspections. Inspector will attempt at a later date.
	Not In Compliance	
	Violation Reference - HSC	

Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:
Total # of Images: 0