



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME <b>IRIS GARDEN</b>				DATE <b>9/21/2012</b>	SIGNATURE
LOCATION <b>12253 TULIP LN, YUCAIPA, CA 92399</b>				REINSPECTION DATE <b>3/21/2013</b>	PERMIT EXPIRATION <b>7/31/2013</b>
MAILING ADDRESS <b>195 N EUCLID AV STE 100, UPLAND CA 91786</b>				REHS <b>Antonio Fields</b>	
FA # <b>FA0016374</b>	PR # <b>PR0021805</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: <b>SPA</b>
TIME IN <b>1:58 PM</b>	TIME OUT <b>2:29 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required




**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

**Recreational Health Details**

Ideal
In Compliance
Not in Compliance



temperature (F)	103.0
observed flow (gpm)	75
required flow (gpm)	No Data
volume (gal)	65,000
area (sq ft)	1,500
occupancy	75

**Inspection Violations**

**Non-critical Violations**

**1. Water Quality - Cyanurates**

Compliance Date not Specified

Not In Compliance

Violation Reference: CCR - 65529(a)

*Violation Description:* The cyanuric acid concentration in any pool shall not exceed 100 ppm.

*Inspector Comments:* Cyanuric acid observed greater than 100ppm. Ensure the cyanuric acid does not exceed 100ppm.

**Overall Inspection Comments**

Influent pressure: 21 psi  
Effluent pressure: 13 psi  
Cyanuric acid: > 100ppm