



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME GOLDEN OLIVE				DATE 9/26/2012	SIGNATURE
LOCATION 2761 GOLDEN AV, SAN BERNARDINO, CA 92404				REINSPECTION DATE 10/10/2012	PERMIT EXPIRATION 9/30/2012
MAILING ADDRESS 744 FOREST VIEW AV, LA PUENTE CA 91746				REHS Nick Thalasinos	
FA # FA0008890	PR # PR0015636	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 10:25 AM	TIME OUT 10:50 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 05 - Corrective Action / Follow up Required
					ACTION: 03 - Reinspection Required


RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	50
volume (gal)	18,270
area (sq ft)	464
occupancy	23

Inspection Violations

Critical Violations

1. Water Quality - Clarity

Compliance Date not Specified
Not In Compliance

Violation Reference: CCR - 65527

Violation Description: The recirculation and purification system shall be operated and maintained so as to keep the pool water clean and clear. The pool may not be used if the main drain is not visible from the deck.

Inspector Comments: Observed water is green, difficult to see the bottom; The pool water must be kept clean and clear.

Non-critical Violations

2. Maintenance - Pool - Sides and Bottom

Compliance Date not Specified
Not In Compliance

Violation Reference: CCR - 65533

Violation Description: The bottom and sides of the pool are to be cleaned as often as necessary to be kept in clean condition. The sides and bottom of pools shall be kept free of slime and algae.

Inspector Comments: Observed water is green; Must clean pool.

Overall Inspection Comments

Pool is currently closed and gate is locked. I spoke to the onsite manager; Directed to clean pool by end of the week.