



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME <b>EMERALD COVE RESORT</b>				DATE <b>9/26/2012</b>	SIGNATURE 
LOCATION <b>2715 PARKER DAM RD, EARP, CA 92242</b>				REINSPECTION DATE <b>3/26/2013</b>	PERMIT EXPIRATION <b>6/30/2013</b>
MAILING ADDRESS <b>PO BOX 1128, PARKER AZ 85344</b>				REHS <b>Hui Chieng</b>	
FA # <b>FA0006118</b>	PR # <b>PR0014895</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: <b>Pool (old)</b>
TIME IN <b>1:45 PM</b>	TIME OUT <b>2:00 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required




**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

**Recreational Health Details**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	65
required flow (gpm)	70
volume (gal)	25,000
area (sq ft)	800
occupancy	40

**Inspection Violations**

**Critical Violations**

**1. Water Quality - Chlorine - low**

Compliance Date not Specified  
Complied on 9/26/2012  
Violation Reference: CCR - 65529(a)

*Violation Description:* Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).  
*Inspector Comments:* Free chlorine concentration was observed at 1.0 ppm. corrected.

**2. Water Quality - pH - high**

Compliance Date not Specified  
Not In Compliance  
Violation Reference: CCR - 65529(a)

*Violation Description:* pH must be maintained between 7.2-8.0 (Ideal is 7.4-7.6).  
*Inspector Comments:* pH was observed at 7.8

**Non-critical Violations**

**3. Safety - Safety Signs**

Compliance Date not Specified  
Not In Compliance  
Violation Reference: CCR 24 - 3119B

*Violation Description:* Safety signs are required to be conspicuously posted and maintained as to be legible: "Warning, No Lifeguard On Duty", "Occupant Load", diagrammatic illustrations of artificial respiration procedures, emergency telephone numbers (ambulance, fire, and police or sheriff's department), warning sign for spa containing "Caution" language, "Emergency Shut-off Switch" for spa. "No Diving Allowed" for shallow pools, "Danger: Gaseous Oxidizer Chlorine" for gas chlorinators, "No Use Of Pool Allowed After Dark" for pools without a light fixture.  
*Inspector Comments:* Post maximum occupancy numbers on the safety signs.

**4. Skimmers - Float Assembly- Air Lock Device**

Compliance Date not Specified  
Not In Compliance  
Violation Reference: CCR 24 - 3134B.1

*Violation Description:* The skimmer shall be provided with an air-lock protective device that shall not permit leakage of air into the recirculation suction piping system. This device shall not leak more than 3 gpm of water during normal operation.  
*Inspector Comments:* Provide float assemblies within the skimmers.

**Overall Inspection Comments**

Report 4 of 4

[EHS would appreciate your feedback on this inspection. Click here to take our survey or browse to surveymonkey.com/s/rehealthsurvey](http://surveymonkey.com/s/rehealthsurvey)