



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME TILTON APARTMENTS					DATE 9/27/2012	SIGNATURE	
LOCATION 32 N SAN MATEO , REDLANDS, CA 92373					REINSPECTION DATE 3/27/2013	PERMIT EXPIRATION 9/30/2012	
MAILING ADDRESS PO BOX 668 , MENTONE CA 92359					<input type="checkbox"/> FACILITY <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT REHS Yong Aday		
FA # FA0008742	PR # PR0015918	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool		
TIME IN 12:18 PM	TIME OUT 12:50 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	45
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

Inspection Violations

Critical Violations

1. Water Quality - Chlorine - high

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR

Violation Description: Free chlorine shall not exceed 10 ppm when pool is open for use.
Inspector Comments: Observed chlorine level at 10.5ppm in pool.

Non-critical Violations

2. Water Quality - Cyanurates

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 65529(a)

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.
Inspector Comments: Observed cyanuric acid level at above 100ppm in pool.

3. Plumbing - Backflow Protection

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR 24 - 3127B

Violation Description: No direct connection between any domestic water supply system and the pool or its piping system is allowed and required to be protected against backflow.
Inspector Comments: Observed a hose attached to a faucet on deck without backflow prevention device. Provide backflow prevention device between the faucet and the hose.

Overall Inspection Comments

No summary comments have been made for this inspection.