



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME <b>FOREST HOME CHRISTIAN CC</b>				DATE <b>10/1/2012</b>	SIGNATURE
LOCATION <b>40000 VALLEY OF THE FALLS DR, FOREST FALLS, CA 92339</b>				REINSPECTION DATE <b>4/01/2013</b>	PERMIT EXPIRATION <b>12/31/2012</b>
MAILING ADDRESS <b>40000 VALLEY OF THE FALLS DR, FOREST FALLS CA 92339</b>				REHS <b>Adela Evans</b>	
FA # <b>FA0008307</b>	PR # <b>PR0003991</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3632</b>	<b>PROGRAM IDENTIFIER: FOREST POOL</b>
TIME IN <b>4:01 PM</b>	TIME OUT <b>4:36 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required




**RECREATIONAL HEALTH - ORGANIZED CAMP POOL**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

**Recreational Health Details**

Ideal
In Compliance
Not in Compliance



temperature (F)	60.0
observed flow (gpm)	300
required flow (gpm)	No Data
volume (gal)	212,960
area (sq ft)	4,380
occupancy	219

**Inspection Violations**

**Critical Violations**

**1. Safety - Life Ring - Requirement**

Compliance Date not Specified  
Not In Compliance  
Violation Reference: CCR - 65539(e)

*Violation Description:* At least one life ring (17 inches in diameter) with line long enough to span the maximum width of the pool shall be provided and maintained. Life rings shall have attached a rope at least 3/16 inch in diameter long enough to span the width of the pool.  
*Inspector Comments:* Life ring was not observed during the inspection. Provide a life ring with an attached rope that spans the maximum width of the pool.

**2. Water Quality - Chlorine - low**

Compliance Date not Specified  
Not In Compliance  
Violation Reference: CCR - 65529(a)

*Violation Description:* Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).  
*Inspector Comments:* Measured a free chlorine concentration of 0.5 ppm while close for use. Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).

**3. Lighting - Pool Light**

Compliance Date not Specified  
Not In Compliance  
Violation Reference: CCR 24 - 3114B.2

*Violation Description:* Pools used at night shall be equipped with underwater light fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots.  
*Inspector Comments:* Observed a dark colored pool light. Repair as necessary and maintain.

**Non-critical Violations**

**4. Safety - Safety Signs**

Compliance Date not Specified  
Not In Compliance  
Violation Reference: CCR 24 - 3119B

*Violation Description:* Safety signs are required to be conspicuously posted and maintained as to be legible: "Warning, No Lifeguard On Duty", "Occupant Load", diagrammatic illustrations of artificial respiration procedures, emergency telephone numbers (ambulance, fire, and police or sheriff's department), warning sign for spa containing "Caution" language, "Emergency Shut-off Switch" for spa. "No Diving Allowed" for shallow pools, "Danger: Gaseous Oxidizer Chlorine" for gas chlorinators, "No Use Of Pool Allowed After Dark" for pools without a light fixture.  
*Inspector Comments:* Provide all the safety signs.

**5. Skimmers - Equalizer Line**

Compliance Date not Specified  
Not In Compliance  
Violation Reference: CCR 24 - 3134B

*Violation Description:* Skimmer(s) shall have an equalizer line with a check valve. For a pool or spa with only one skimmer, the equalizer line must have an approved anti-vortex cover or a split equalizer line.  
*Inspector Comments:* Replace the missing check valves.

**CONTINUES...**

[EHS would appreciate your feedback on this inspection. Click here to take our survey or browse to \[surveymonkey.com/s/rehealthsurvey\]\(http://surveymonkey.com/s/rehealthsurvey\)](#)



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME <b>FOREST HOME CHRISTIAN CC</b>	DATE <b>10/1/2012</b>	SIGNATURE
LOCATION <b>40000 VALLEY OF THE FALLS DR, FOREST FALLS, CA 92339</b>	REHS <b>Adela Evans</b>	

**Inspection Violations (Continued)**

**Non-critical Violations**

**6. Water - Supply - Showers / Lavatories**

**Compliance Date not Specified**      *Violation Description:* Showers and lavatories are required to have hot and cold potable running water. Water temperature shall not exceed 110°F.  
**Not In Compliance**  
 Violation Reference: CCR - 3115B.4.1      *Inspector Comments:* Observed a maximum hot water temperature of 70F at the hand sink in the women's restroom. Restore hot water and maintain.

**7. Decking - Requirement**

**Compliance Date not Specified**      *Violation Description:* The deck shall be a minimum 4 feet wide (clear and unobstructed), slip resistant, non-abrasive, sloped away from the pool and maintained clean and in good repair. (Exception – only 50% around a spa, none for a temporary training pool)  
**Not In Compliance**  
 Violation Reference: CCR - 3113B      *Inspector Comments:* Observed cracked/damaged decking. Repair and maintain.

**8. Employee - Lifeguards - Requirement**

**Compliance Date not Specified**      *Violation Description:* All pools where a direct fee is charged for the use of the facility shall provide an adequate number of lifeguards (1/50 bathers). Lifeguards must have current Red Cross or YMCA certificates and are trained in first aid and CPR.  
**Not In Compliance**  
 Violation Reference: CCR - 116045      *Inspector Comments:* Did not observe life guard certifications during the inspection. Fax/email within 30 days.

**Overall Inspection Comments**

Additional Observations:

Cyanuric Acid: < 30 ppm  
 Influent Gauge: 10 psi  
 Effluent Gauge: 8 psi  
 Differential Pressures: 2 psi  
 Flow Meter: ~ 300 gpm (observed by on-site operator).

Due to the location of the flow meter, it was difficult to get clear reading. Provide an approved flow rate. If the pool is pre-1982, required flow rate is approximately 444 gpm. If the pool is post-1982, required flow rate is approximately 592 gpm.

Also, observed portions of the fence bulding inwards (i.e. from a large tree branch). Repair as needed and maintain.

NOTE: Pool was closed for use during the inspection. Per on-site operator, camp anticipates demolishing pool by the end of this year and building a new pool in a separate location by next summer. Ensure that proper permits have been pulled and appropriate enforcing agencies (i.e. San Bernardino County Plan Check, Building & Safety, etc.) have been notified prior to beginning the demolition. Also, ensure that new pool meets all current requirements prior to opening. For any questions or concerns, contact San Bernardino Environmental Health Services at 1-800-442-2283.