



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME CARRIAGE TRADE MANOR MHP				DATE 10/4/2012	SIGNATURE
LOCATION 12874 CALIFORNIA ST, YUCAIPA, CA 92399				REINSPECTION DATE 10/18/2012	PERMIT EXPIRATION 12/31/2012
MAILING ADDRESS 12874 CALIFORNIA ST, YUCAIPA, CA 92399				REHS Nick Thalasin	
FA # FA0007217	PR # PR0014703	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 3:37 PM	TIME OUT 4:20 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 05 - Corrective Action / Follow up Required
					ACTION: 14 - Permit Suspd / Facility Closed fencing iss



RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	66
volume (gal)	31,860
area (sq ft)	792
occupancy	40

Inspection Violations

Health Permit to Operate has been SUSPENDED

1. Permit - Suspension

Compliance Date not Specified
Not In Compliance
Violation Reference: HSC

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

Inspector Comments:

Critical Violations

2. Enclosure - Gates & Doors - Self-Closing/Latching

Comply by 10/5/2012
Not In Compliance
Violation Reference: CCR - 3118.2(1)

Violation Description: Gates and/or doors shall be self-closing and self-latching to securely close. Gates and doors shall open away from the pool.

Inspector Comments: Observed the gate is not self-latching; Gates and/or doors shall be self-closing and self-latching to securely close.

3. Water Quality - Chlorine - high

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR

Violation Description: Free chlorine shall not exceed 10 ppm when pool is open for use.

Inspector Comments: Observed free chlorine is greater than 10 ppm; Free chlorine shall not exceed 10 ppm when pool is open for use.

Non-critical Violations

4. Maintenance - Pool - Sides and Bottom

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 65533

Violation Description: The bottom and sides of the pool are to be cleaned as often as necessary to be kept in clean condition. The sides and bottom of pools shall be kept free of slime and algae.

Inspector Comments: Observed dark algae like grows on the sides and bottom of the pool; Clean as needed.

CONTINUES...

[EHS would appreciate your feedback on this inspection. Click here to take our survey or browse to \[surveymonkey.com/s/rehealthsurvey\]\(http://surveymonkey.com/s/rehealthsurvey\)](#)



County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME CARRIAGE TRADE MANOR MHP	DATE 10/4/2012	SIGNATURE
LOCATION 12874 CALIFORNIA ST, YUCAIPA, CA 92399	REHS Nick Thalasinis	

Inspection Violations (Continued)

Non-critical Violations

5. Water Quality - Cyanurates

Compliance Date not Specified

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

Not In Compliance

Inspector Comments: The cyanuric acid exceeds 100 ppm; The cyanuric acid concentration in any pool shall not exceed 100 ppm.

Violation Reference: CCR -
65529(a)

Overall Inspection Comments

The Permit is SUSPENDED and the Pool is CLOSED.