



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME GOLDEN OLIVE				DATE 10/10/2012	SIGNATURE
LOCATION 2761 GOLDEN AV, SAN BERNARDINO, CA 92404				REINSPECTION DATE 3/10/2013	PERMIT EXPIRATION 9/30/2013
MAILING ADDRESS 744 FOREST VIEW AV, LA PUENTE CA 91746				REHS Nick Thalasin	
FA # FA0008890	PR # PR0015636	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 9:48 AM	TIME OUT 10:12 AM	CONTACT Not Captured			SERVICE: 037 - Pool/Spa - Other Inspection Services
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 15 - Permit Reinstated / Facility Re-opened




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	50
volume (gal)	18,270
area (sq ft)	464
occupancy	23

Inspection Violations

Health Permit to Operate has been REINSTATED

1. Permit Reinstatement

Compliance Date not Specified
Not In Compliance
Violation Reference: HSC

Violation Description: The health permit to operate is hereby reinstated and facility may open.
Inspector Comments:

A Re-Reinspection has been conducted on this date

2. Re-Reinspection

Compliance Date not Specified
Not In Compliance
Violation Reference: HSC

Violation Description: Billable re-reinspection conducted at this time to determine compliance from prior reinspection.
Inspector Comments:

Non-critical Violations

3. Maintenance - Pool - Sides and Bottom

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 65533

Violation Description: The bottom and sides of the pool are to be cleaned as often as necessary to be kept in clean condition. The sides and bottom of pools shall be kept free of slime and algae.
Inspector Comments: Observed the pool shell exhibits algae like growths; The bottom and sides of the pool are to be cleaned as often as necessary to be kept in clean condition.

Overall Inspection Comments

No summary comments have been made for this inspection.

[EHS would appreciate your feedback on this inspection. Click here to take our survey or browse to \[surveymonkey.com/s/rehealthsurvey\]\(http://surveymonkey.com/s/rehealthsurvey\)](#)