



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME LINCOLN ELEMENTARY SCHOOL				DATE 11/6/2012	SIGNATURE
LOCATION 440 N ALLYN ST, ONTARIO, CA 91764				REINSPECTION DATE 5/06/2013	PERMIT EXPIRATION
MAILING ADDRESS 950 W D ST, ONTARIO CA 91762				REHS Nicole Walker	
FA # FA0002540	PR # PR0016970	SR # Not Specified	CO # Not Specified	PE 3603	PROGRAM IDENTIFIER: Pool
TIME IN 10:38 AM	TIME OUT 11:38 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required



RECREATIONAL HEALTH - PUBLIC SCHOOL POOL / SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

Ideal
In Compliance
Not in Compliance



temperature (F)	90.0
observed flow (gpm)	95
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

Inspection Violations

Non-critical Violations

1. Skimmers - Float Assembly- Air Lock Device

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR 24 - 3134B.1

Violation Description: The skimmer shall be provided with an air-lock protective device that shall not permit leakage of air into the recirculation suction piping system. This device shall not leak more than 3 gpm of water during normal operation.
Inspector Comments: Observed missing at small pool.

2. Restrooms - Toilet Facilities - Supplies

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 65551©

Violation Description: Handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues are required in permanently installed dispensing devices.
Inspector Comments: Store toilet paper properly at wall mounted dispenser device. Not observed at girls' restroom.

Overall Inspection Comments

NOTE: Observed pooling water along deck. Maintain well maintained.