



**County of San Bernardino • Department of Public Health**  
**Division of Environmental Health Services**  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME <b>REDLANDS HIGH SCHOOL</b>					DATE <b>12/11/2012</b>	SIGNATURE	
LOCATION <b>840 E CITRUS AV, REDLANDS, CA 92373</b>					REINSPECTION DATE <b>6/11/2013</b>	PERMIT EXPIRATION	
MAILING ADDRESS <b>840 E CITRUS AV, REDLANDS, CA 92373</b>					REHS <b>Yong Aday</b>		
FA # <b>FA0006492</b>	PR # <b>PR0014837</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3603</b>	PROGRAM IDENTIFIER: <b>Deep pool</b>		
TIME IN <b>10:46 AM</b>	TIME OUT <b>11:17 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		




**RECREATIONAL HEALTH - PUBLIC SCHOOL POOL / SPA**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

**Recreational Health Details**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	592
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**Inspection Violations**

**Non-critical Violations**

**1. Water - Supply - Showers / Lavatories**

Compliance Date not Specified  
Not In Compliance  
Violation Reference: CCR - 3115B.4.1

*Violation Description:* Showers and lavatories are required to have hot and cold potable running water. Water temperature shall not exceed 110°F.

*Inspector Comments:* Observed only cold water at hand washing sinks in restrooms.

**Overall Inspection Comments**

Note: Cyanuric acid level at below 30ppm.