



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

| | | | | | |
|----------------------------------------------------------------------|----------------------------|--------------------------------|------------------------------|---------------------------------------|---------------------------------------------------------------|
| FACILITY NAME KENDALL PALMS APARTMENTS | | | | DATE 12/27/2012 | SIGNATURE <i>Adela Evans</i> |
| LOCATION 3943 N H ST, SAN BERNARDINO, CA 92404 | | | | REINSPECTION DATE 6/27/2013 | PERMIT EXPIRATION 1/31/2013 |
| MAILING ADDRESS 8504 FIRESTONE BL STE 161, DOWNEY CA 90241 | | | | REHS Adela Evans | |
| FA # FA0008920 | PR # PR0013853 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: pool |
| TIME IN 2:50 PM | TIME OUT 3:39 PM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required |
| | | | | | ACTION: 01 - No Further Action Required |




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | 49.0 |
| observed flow (gpm) | No Data |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | No Data |

Inspection Violations

Critical Violations

1. Enclosure - Fence Openings/Holes/Gaps

Comply by 12/28/2012

Not In Compliance

Violation Reference: CCR 24 - 3118B(a)2

Violation Description: Openings, holes, or gaps in the enclosure shall not allow the passage of a 4 inch diameter sphere. The bottom of the enclosure shall be within 2 inches of the finished grade.

Inspector Comments: Observed a portion of the fence slightly loose. Pool was closed by the operator. Per operator, fence will be replaced. Repair and/or replace fence prior to open.

Contact San Bernardino County Plan Check at 1-800-442-2283 to ensure compliance prior to replacing the fence.

2. Safety - Life Ring - Requirement

Compliance Date not Specified

Not In Compliance

Violation Reference: CCR - 65539(e)

Violation Description: At least one life ring (17 inches in diameter) with line long enough to span the maximum width of the pool shall be provided and maintained. Life rings shall have attached a rope at least 3/16 inch in diameter long enough to span the width of the pool.

Inspector Comments: Observed rope missing from the life ring. Supply and maintain.

3. Water Quality - Chlorine - low

Compliance Date not Specified

Not In Compliance

Violation Reference: CCR - 65529(a)

Violation Description: Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).

Inspector Comments: Measure 0.5 ppm chlorine while the pool was closed for use. Prior to opening, ensure the chlorine is maintained between 1.5ppm-10ppm.

Non-critical Violations

4. Equipment - Flow Meter

Compliance Date not Specified

Not In Compliance

Violation Reference: CCR 24 - 3124B

Violation Description: The recirculation system is required to have a flow meter, accurate within 10 percent of actual flow located on the return line.

Inspector Comments: Observed stuck flow meter. Repair and maintain.

5. Safety - Safety Signs

Compliance Date not Specified

Not In Compliance

Violation Reference: CCR 24 - 3119B

Violation Description: Safety signs are required to be conspicuously posted and maintained as to be legible: "Warning, No Lifeguard On Duty", "Occupant Load", diagrammatic illustrations of artificial respiration procedures, emergency telephone numbers (ambulance, fire, and police or sheriff's department), warning sign for spa containing "Caution" language, "Emergency Shut-off Switch" for spa. "No Diving Allowed" for shallow pools, "Danger: Gaseous Oxidizer Chlorine" for gas chlorinators, "No Use Of Pool Allowed After Dark" for pools without a light fixture.

Inspector Comments: Observed occupancy load missing from the sign. Provide maintain.

CONTINUES...



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

| | | | |
|----------------------------------------------------------|--|----------------------------|---------------|
| FACILITY NAME KENDALL PALMS APARTMENTS | | DATE 12/27/2012 | SIGNATURE |
| LOCATION 3943 N H ST, SAN BERNARDINO, CA 92404 | | REHS Adela Evans | |

Inspection Violations (Continued)

Non-critical Violations

6. Water Quality - Cleanliness - Pool Surface

**Compliance Date not Specified
Not In Compliance**

Violation Reference: CCR -
65533

Violation Description: Floating scum, sputum, or debris are not allowed to accumulate in the pool. Skimmers shall be maintained and operated to remove such material continuously.

Inspector Comments: Observed the bottom of the pool covered in leaves. Clean and maintain.

NOTE: Skimmers were full of debris during the inspection. Maintain clean, and ensure a proper float assembly and check valve is installed in each skimmer prior to opening.

Overall Inspection Comments

NOTE: Pool was observed closed and locked upon arrival. Per operator, pool may re-open in the summer. Ensure the pool meets current requirements prior to opening.

Influent Gauge: 12 psi

Effluent Gauge: 7 psi

Differential Pressure: 5 psi

Flow Meter: Stuck

(Ensure the recirculation system is not closed looped).

Maintain daily records of routine maintenance.