



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME HILTON GARDEN INN SAN BERNARDINO				DATE 2/1/2013	SIGNATURE
LOCATION 1755 S WATERMAN AV, SAN BERNARDINO, CA 92408				REINSPECTION DATE 8/01/2013	PERMIT EXPIRATION 7/31/2013
MAILING ADDRESS 42 CORPORATE PARK STE 200, IRVINE CA 92606				REHS Marilyn Krichbaum	
FA # FA0018426	PR # PR0024474	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: SPA
TIME IN 11:20 AM	TIME OUT 11:45 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

Ideal
In Compliance
Not in Compliance



temperature (F)	105.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

Inspection Violations

Critical Violations

1. Water Quality - pH - high

Compliance Date not Specified

Not In Compliance

Violation Reference: CCR - 65529(a)

Violation Description: pH must be maintained between 7.2-8.0 (Ideal is 7.4-7.6).

Inspector Comments: Observed a high ph level of 8.0 Lower the ph level so that it is 7.4-7.6. Acid was added to the spa.

2. Temperature - Spa Water Requirement

Compliance Date not Specified

Not In Compliance

Violation Reference: CCR 24 - 3135B.2

Violation Description: Water temperature shall not exceed 104°F.

Inspector Comments: Observed a spa temperature of 105F. Lower the temperature so that it does not exceed 104F. Employee adjusted the temperature of the spa heater.

3. Lighting - Pool Light

Compliance Date not Specified

Not In Compliance

Violation Reference: CCR 24 - 3114B.2

Violation Description: Pools used at night shall be equipped with underwater light fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots.

Inspector Comments: Replace the burned out spa light.

Non-critical Violations

4. Access - Hand Rail - Shallow End

Compliance Date not Specified

Not In Compliance

Violation Reference: CCR - 3110B.1

Violation Description: Entry and exit to and from the pool are required in the shallowest portion of the pool. Handrails are required at the top of both sides and extend over the coping or edge of the deck. Handrails must be maintained in good repair.

Inspector Comments: Secure the loose handrail.

5. Safety - Safety Signs

Compliance Date not Specified

Not In Compliance

Violation Reference: CCR 24 - 3119B

Violation Description: Safety signs are required to be conspicuously posted and maintained as to be legible: "Warning, No Lifeguard On Duty", "Occupant Load", diagrammatic illustrations of artificial respiration procedures, emergency telephone numbers (ambulance, fire, and police or sheriff's department), warning sign for spa containing "Caution" language, "Emergency Shut-off Switch" for spa. "No Diving Allowed" for shallow pools, "Danger: Gaseous Oxidizer Chlorine" for gas chlorinators, "No Use Of Pool Allowed After Dark" for pools without a light fixture.

Inspector Comments: Observed that the lettering for the spa capacity was small. The lettering for this sign must be 4 inches high so people can read it.

CONTINUES...



County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME HILTON GARDEN INN SAN BERNARDINO	DATE 2/1/2013	SIGNATURE 
LOCATION 1755 S WATERMAN AV, SAN BERNARDINO, CA 92408	REHS Marilyn Krichbaum	

Overall Inspection Comments

No summary comments have been made for this inspection.