



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME HILTON GARDEN INN SAN BERNARDINO					DATE 2/1/2013	SIGNATURE 	
LOCATION 1755 S WATERMAN AV, SAN BERNARDINO, CA 92408					REINSPECTION DATE 8/01/2013	PERMIT EXPIRATION 7/31/2013	
MAILING ADDRESS 42 CORPORATE PARK STE 200, IRVINE CA 92606					<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS Marilyn Krichbaum		
FA # FA0018426	PR # PR0024475	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: POOL		
TIME IN 11:45 AM	TIME OUT 12:30 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	40
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

Inspection Violations

Non-critical Violations

1. Access - Hand Rail - Shallow End

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 3110B.1

Violation Description: Entry and exit to and from the pool are required in the shallowest portion of the pool. Handrails are required at the top of both sides and extend over the coping or edge of the deck. Handrails must be maintained in good repair.
Inspector Comments: Secure the loose handrails.

2. Safety - Safety Signs

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR 24 - 3119B

Violation Description: Safety signs are required to be conspicuously posted and maintained as to be legible: "Warning, No Lifeguard On Duty", "Occupant Load", diagrammatic illustrations of artificial respiration procedures, emergency telephone numbers (ambulance, fire, and police or sheriff's department), warning sign for spa containing "Caution" language, "Emergency Shut-off Switch" for spa. "No Diving Allowed" for shallow pools, "Danger: Gaseous Oxidizer Chlorine" for gas chlorinators, "No Use Of Pool Allowed After Dark" for pools without a light fixture.
Inspector Comments: Observed that the pool capacity sign was in small lettering. This sign must be in lettering 4 inches high so that the public can read it.

Overall Inspection Comments

No summary comments have been made for this inspection.