



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME <b>FAIRWAY MOBILE HOME ESTATES</b>				DATE <b>3/26/2013</b>	SIGNATURE <i>Cheryl Selverus</i>
LOCATION <b>26297 BASELINE AV, HIGHLAND, CA 92346</b>				REINSPECTION DATE <b>9/26/2013</b>	PERMIT EXPIRATION <b>2/28/2014</b>
MAILING ADDRESS <b>PO BOX 1919, RANCHO CUCAMONGA CA 91729-1919</b>				REHS <b>Dior Porter</b>	
FA # <b>FA0007189</b>	PR # <b>PR0013959</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: <b>pool</b>
TIME IN <b>1:35 PM</b>	TIME OUT <b>2:20 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required




**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

**Recreational Health Details**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	90
volume (gal)	43,443
area (sq ft)	1,056
occupancy	52

**Inspection Violations**

**Non-critical Violations**

**1. Maintenance - Toilet / Shower / Dressing Facility**

**Compliance Date not Specified**  
**Not In Compliance**  
Violation Reference: CCR - 65535(c), 65551

*Violation Description:* Toilets, urinals, showers, wash basins and other plumbing fixtures are to be maintained in a clean condition, and in good repair. Walls, partitions, doors, lockers and similar surfaces that require periodic cleaning shall be maintained smooth and finished so as to facilitate cleaning. Areas are to be kept clean.

*Inspector Comments:* Observed inoperable toilets and missing shower head and faucet fixtures. Repair/Replace.

**2. Restrooms - Toilet Facilities - Supplies**

**Compliance Date not Specified**  
**Not In Compliance**  
Violation Reference: CCR - 65551©

*Violation Description:* Handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues are required in permanently installed dispensing devices.

*Inspector Comments:* Observed missing soap and towels in both restrooms. Provide and maintain

**Overall Inspection Comments**

Pump on a timer and off at time of inspection.