



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME FAIRFIELD INN & SUITES TWENTYNINE PALMS					DATE 3/27/2013	SIGNATURE 	
LOCATION 6333 ENCELIA AV, TWENTYNINE PALMS, CA 92277					REINSPECTION DATE 4/10/2013	PERMIT EXPIRATION 7/31/2013	
MAILING ADDRESS 6333 ENCELIA AV, TWENTYNINE PALMS CA 92277					<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS Chaz Harrison		
FA # FA0017224	PR # PR0023290	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: SPA		
TIME IN 2:40 PM	TIME OUT 3:19 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 05 - Corrective Action / Follow up Required		
					ACTION: 13 - Permit Suspended / Facility Closed		



RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

Inspection Violations

Critical Violations

1. Water Quality - Chlorine - low

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 65529(a)

Violation Description: Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).

Inspector Comments: Observed 0ppm chlorine. Ensure chlorine is maintained between 1.5 and 10ppm.

2. Water Quality - pH - high

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 65529(a)

Violation Description: pH must be maintained between 7.2-8.0 (Ideal is 7.4-7.6).

Inspector Comments: Observed pH above 8. Ensure pH is maintained between 7.2-8.0

Non-critical Violations

3. Equipment - Spa Heater

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR

Violation Description: Spa Heater shall be functional. By definition a spa-pool contains water of elevated temperature.

Inspector Comments: Observed non functioning heater. Repair/replace.

Overall Inspection Comments

Contact Chaz Harrison at 1800-442-2283 with any questions.