



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

| | | | | | | | |
|--|-----------------------------|--------------------------------|------------------------------|-------------------|--|---------------------------------------|--|
| FACILITY NAME INLAND EMPIRE JOB CORPS | | | | | DATE 3/28/2013 | SIGNATURE | |
| LOCATION 3173 KERRY ST, SAN BERNARDINO, CA 92407 | | | | | REINSPECTION DATE 9/28/2013 | PERMIT EXPIRATION 6/30/2013 | |
| MAILING ADDRESS 3173 KERRY ST, SAN BERNARDINO CA 92407 | | | | | REHS Yong Aday | | |
| FA # FA0005610 | PR # PR0007348 | SR # Not Specified | CO # Not Specified | PE 3632 | PROGRAM IDENTIFIER: Pool | | |
| TIME IN 10:46 AM | TIME OUT 11:20 AM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine | | |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required | | |
| | | | | | ACTION: 01 - No Further Action Required | | |




RECREATIONAL HEALTH - ORGANIZED CAMP POOL

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | 60 |
| required flow (gpm) | 140 |
| volume (gal) | No Data |
| area (sq ft) | 1,800 |
| occupancy | 90 |

Inspection Violations

Non-critical Violations

1. Water Quality - Cyanurates

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 65529(a)

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.
Inspector Comments: Observed cyanuric acid level at above 100ppm in pool.

2. Structure - Tile

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 3106B.2

Violation Description: Waterline tile shall be cleaned and maintained in good repair.
Inspector Comments: Replace missing and damaged waterline tiles.

3. Equipment - Flow Rate / Turnover Time

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR 24 - 3124B

Violation Description: The recirculation and purification system shall have sufficient flow rate to provide a complete turnover of pool water in 30 minutes or less for a spa pool, 1 hour or less for a wading pool, 2 hours or less for a temporary training pool, and 6 hours or less far all other types of public pools.
Inspector Comments: Observed recirculation flow rate at 60GPM. Provide at least 140GPM flow rate to ensure 6 hours of turnover rate.

Overall Inspection Comments

No summary comments have been made for this inspection.