



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME COUNTRY INN & SUITES					DATE 3/28/2013	SIGNATURE 	
LOCATION 1650 INDUSTRIAL PKWY, REDLANDS, CA 92374					REINSPECTION DATE 9/28/2013	PERMIT EXPIRATION 2/28/2013	
MAILING ADDRESS 1260 ALABAMA ST, REDLANDS CA 92374					<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS Marilyn Krichbaum		
FA # FA0014943	PR # PR0020093	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool		
TIME IN 9:50 AM	TIME OUT 11:15 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		




RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	60
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

Inspection Violations

Critical Violations

1. Safety - Life Ring - Requirement

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 65539(e)

Violation Description: At least one life ring (17 inches in diameter) with line long enough to span the maximum width of the pool shall be provided and maintained. Life rings shall have attached a rope at least 3/16 inch in diameter long enough to span the width of the pool.

Inspector Comments: Replace the missing life ring and rope in the pool area.

2. Safety - Rescue Pole

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 65539(e)

Violation Description: At least one rescue pole not less than 12 continuous feet in length with body hook permanently attached shall be provided and maintained.

Inspector Comments: Replace the missing rescue pole in the pool area.

3. Lighting - Pool Light

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR 24 - 3114B.2

Violation Description: Pools used at night shall be equipped with underwater light fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots.

Inspector Comments: Replace the burned out light in the pool. Make sure the gfci works.

Non-critical Violations

4. Safety - Safety Signs

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR 24 - 3119B

Violation Description: Safety signs are required to be conspicuously posted and maintained as to be legible: "Warning, No Lifeguard On Duty", "Occupant Load", diagrammatic illustrations of artificial respiration procedures, emergency telephone numbers (ambulance, fire, and police or sheriff's department), warning sign for spa containing "Caution" language, "Emergency Shut-off Switch" for spa. "No Diving Allowed" for shallow pools, "Danger: Gaseous Oxidizer Chlorine" for gas chlorinators, "No Use Of Pool Allowed After Dark" for pools without a light fixture.

Inspector Comments: Replace the missing pool capacity number on sign. Pool capacity is calculated by taking the area and dividing 20.

Two new pool signs will be required. See our website.

CONTINUES...



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME COUNTRY INN & SUITES	DATE 3/28/2013	SIGNATURE
LOCATION 1650 INDUSTRIAL PKWY, REDLANDS, CA 92374		REHS Marilyn Krichbaum

Inspection Violations (Continued)

Non-critical Violations

5. Water Quality - Cyanurates

Compliance Date not Specified

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

Not In Compliance

Inspector Comments: Observed a cyanuric acid level greater than 100ppm. Lower the cyanuric acid level so that it does not exceed 100ppm.

Violation Reference: CCR - 65529(a)

6. Restrooms - Toilet Facilities - Supplies

Compliance Date not Specified

Violation Description: Handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues are required in permanently installed dispensing devices.

Not In Compliance

Inspector Comments: Provide soap in both restrooms. Observed no soap.

Violation Reference: CCR - 65551©

Overall Inspection Comments

No summary comments have been made for this inspection.