



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME DESERT VISTA VILLAGE				DATE 4/1/2013	SIGNATURE
LOCATION 7345 PALM AV, YUCCA VALLEY, CA 92284				REINSPECTION DATE 4/15/2013	PERMIT EXPIRATION 7/31/2013
MAILING ADDRESS PO BOX 90250, HENDERSON NV 89009				REHS Dior Porter	
FA # FA0017228	PR # PR0023256	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Spa
TIME IN 1:36 PM	TIME OUT 1:54 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 05 - Corrective Action / Follow up Required
					ACTION: 13 - Permit Suspended / Facility Closed



RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50

Recreational Health Details

Ideal
In Compliance
Not in Compliance



temperature (F)	99.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

Inspection Violations

Health Permit to Operate has been SUSPENDED

1. Permit - Suspension

Compliance Date not Specified
Not In Compliance
Violation Reference: HSC

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

Inspector Comments: Permit suspended due to 0ppm chlorine. Closure sign posted, do not remove. Provide 1.0 (1.5 with cyanuric acid)-10ppm chlorine. Contact department of Environmental Health at 800-442-2283 when correction has been made and facility is ready for reinspection. Facility may only be reopened by Environmental Health Specialist.

Critical Violations

2. Water Quality - Chlorine - low

Compliance Date not Specified
Not In Compliance
Violation Reference: CCR - 65529(a)

Violation Description: Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).

Inspector Comments: Observed 0ppm chlorine. Closure sign posted, do not remove. Provide 1.0 (1.5 with cyanuric acid)-10ppm chlorine. Contact department of Environmental Health at 800-442-2283 when correction has been made and facility is ready for reinspection. Facility may only be reopened by Environmental Health Specialist.

Overall Inspection Comments

unable to access pump room