



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dehs

(800) 442-2283

| | | | | | | | |
|---|-----------------------------|--------------------------------|------------------------------|-------------------|--|---------------------------------------|--|
| FACILITY NAME PESCADERIA MR FISH | | | | | DATE 4/10/2013 | SIGNATURE <i>Sierra Clayborn</i> | |
| LOCATION 16339 ARROW WY B, FONTANA, CA 92335 | | | | | REINSPECTION DATE 9/10/2013 | PERMIT EXPIRATION 6/30/2013 | |
| MAILING ADDRESS 16339 ARROW WY B, FONTANA, CA 92335 | | | | | <input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT REHS Sierra Clayborn | | |
| FA # FA0003541 | PR # PR0002218 | SR # Not Specified | CO # Not Specified | PE 1610 | PROGRAM IDENTIFIER: market | | |
| TIME IN 12:30 PM | TIME OUT 12:40 PM | CONTACT Not Captured | | | SERVICE: 003 - Inspection - Follow Up Inspection | | |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required | | |
| | | | | | ACTION: 01 - No Further Action Required | | |

RETAIL FOOD PROTECTION - FOOD HANDLING PL (0-499 SQFT)

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Inspection Violations

Violations or Observations without a specified degree

1. Hot and cold water available

Compliance Date not Specified
 Not In Compliance

Violation Description: An adequate, protected, pressurized, potable supply of hot water and cold water shall be provided at all times. (113953(c), 114099.2(b) 114101(a), 114189, 114192, 114192.1, 114195)

Violation Reference: HSC - 113953(c), 114099.2(b)

Inspector Comments: Observation inspection performed today to confirm compliance for hot water requirement of 120 F.

Overall Inspection Comments

Observed hot water at 120 F at hand sink, 131 F at mop sink and 128 F at 3 compartment sink. Facility is in compliance with hot water requirement at this time.

Observed leak of hot water valve/faucet at 3 compartment sink. Repair as soon as possible.