



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs



(800) 442-2283

FACILITY NAME PARC MOUNTAIN VIEW APTS				DATE 4/22/2013	SIGNATURE
LOCATION 25941 BASELINE ST, HIGHLAND, CA 92346				REINSPECTION DATE 10/22/2013	PERMIT EXPIRATION 1/31/2014
MAILING ADDRESS 2016 RIVERSIDE DR, LOS ANGELES CA 90039				REHS Dior Porter	
FA # FA0004456	PR # PR0013528	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 4:13 PM	TIME OUT 4:50 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
				RESULT: 03 - Corrective Action / No Follow up Required	
				ACTION: 01 - No Further Action Required	

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	67
volume (gal)	24,000
area (sq ft)	650
occupancy	32

36K995 Permit - Suspension



POINTS
NA

Compliance Date not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: Observed 0ppm chlorine. Provide 1.0-10ppm (1.5 minimum with cyanuric acid) Permit suspended until verified corrected by Environmental Health Specialist. Contact Department of Environmental Health at 800-442-2283 when violation has been corrected and facility is ready for re-inspection. Violation to be corrected within 1 week.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K101 Safety - Rescue Pole



POINTS
NA

Compliance Date not Specified
Not In Compliance
Violation Reference - CCR - 65539(e)

Inspector Comments: Observed missing hook to rescue pole. Provide. REPEAT violation, failure to correct will result in office hearing.

Violation Description: At least one rescue pole not less than 12 continuous feet in length with body hook permanently attached shall be provided and maintained.

36K123 Water Quality - Chlorine - low



POINTS
NA

Compliance Date not Specified
Not In Compliance
Violation Reference - CCR - 65529(a)

Inspector Comments: Observed 0ppm chlorine. Provide 1.0-10ppm (1.5 minimum with cyanuric acid) Permit suspended until verified corrected. Contact Department of Environmental Health at 800-442-2283 when violation has been corrected and facility is ready for re-inspection. Violation to be corrected within 1 week.

Violation Description: Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).

36K124 Water Quality - Clarity



POINTS
NA

Compliance Date not Specified
Not In Compliance
Violation Reference - CCR - 65527

Inspector Comments: Observed an excessive amount of debris inside of the pool. Clean and maintain. REPEAT violation, failure to correct will result in office hearing.

Violation Description: The recirculation and purification system shall be operated and maintained so as to keep the pool water clean and clear. The pool may not be used if the main drain is not visible from the deck.



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME PARC MOUNTAIN VIEW APTS	DATE 4/22/2013	SIGNATURE
LOCATION 25941 BASELINE ST, HIGHLAND, CA 92346	REHS Dior Porter	

36K083 Equipment - Flow Meter functioning

POINTS NA	Compliance Date not Specified	Inspector Comments: Observed stuck flow meter. Repair/replace. REPEAT violation, failure to correct will result in office hearing.
	Not In Compliance	
	Violation Reference - CCR	

Violation Description: The flow meter must be maintained functional and in good repair.

36K170 Decking - Requirement

POINTS NA	Compliance Date not Specified	Inspector Comments: Observed cracked, damaged deck near pump area. Repair. REPEAT violation, failure to correct will result in office hearing.
	Not In Compliance	
	Violation Reference - CCR - 3113B	

Violation Description: The deck shall be a minimum 4 feet wide (clear and unobstructed), slip resistant, non-abrasive, sloped away from the pool and maintained clean and in good repair. (Exception – only 50% around a spa, none for a temporary training pool)

Overall Inspection Comments

Please contact your inspector at 800-442-2283

Photo Attachments:

No Photo Attachments