



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**




[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>MONTEREY VILLAS APTS</b>				DATE <b>4/23/2013</b>	SIGNATURE
LOCATION <b>7000 LA PRAIX , HIGHLAND, CA 92346</b>				REINSPECTION DATE <b>10/23/2013</b>	PERMIT EXPIRATION <b>5/31/2013</b>
MAILING ADDRESS <b>1 ORCHARD 230, LAKE FOREST CA 92630-8300</b>				REHS <b>Dior Porter</b>	
FA # <b>FA0005742</b>	PR # <b>PR0013510</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: pool
TIME IN <b>4:16 PM</b>	TIME OUT <b>4:40 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	50
volume (gal)	17,854
area (sq ft)	616
occupancy	20

**36K048 Enclosure - Fence Height**

**⚠ CRITICAL ⚠**

**POINTS**  
**NA**

Compliance Date not Specified  
Not In Compliance  
Violation Reference - CCR 24 - 3118B(a)1

**Inspector Comments:** Observed damaged fencing at bottom edge of fence on the side adjacent to the main entrance. Repair immediately.

**Violation Description:** The pool shall be enclosed by one or a combination of one of the following: a fence, portion of a building, wall or other approved durable enclosure. Doors, openable windows, or gates of living quarters or associated private premises shall not be permitted as part of the pool enclosure. The enclosure, doors and gates shall meet all of the following specifications:

1. The enclosure shall have a minimum effective perpendicular height of 5 meet as measured from the outside. For details see Title 24, section 3118B, Figures 31B-4 and 31B-5.

**36K056 Maintenance - Record Keeping**

**POINTS**  
**NA**

Compliance Date not Specified  
Not In Compliance  
Violation Reference - CCR - 65523(a)

**Inspector Comments:** Observed missing entries for the month of April. Maintain an accurate daily record of all chemicals used.

**Violation Description:** The operator of each pool open for use shall keep an accurate daily record of information regarding operation, including readings of disinfectant residual, pH, and maintenance procedures such as cleaning of filters and quantity of chemicals used. If cyanuric acid is used it shall be measured a minimum of once per month. Data shall be maintained at least a year for inspection by DEHS.

**36K076 Equipment - Flow Meter**

**POINTS**  
**NA**

Compliance Date not Specified  
Not In Compliance  
Violation Reference - CCR 24 - 3124B

**Inspector Comments:** Observed missing flow meter. Install flow meter on return line.

**Violation Description:** The recirculation system is required to have a flow meter, accurate within 10 percent of actual flow located on the return line.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments