



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283



www.sbcounty.gov/dehs

FACILITY NAME TRINITY CHILDREN & FAMILY					DATE 4/23/2013	SIGNATURE	
LOCATION 10776 N FREMONT AV, YUCAIPA, CA 92399					REINSPECTION DATE 10/23/2013	PERMIT EXPIRATION 12/31/2013	
MAILING ADDRESS 10776 N FREMONT AV, YUCAIPA, CA 92399					REHS Antonio Fields		
FA # FA0007293	PR # PR0014664	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool		
TIME IN 10:11 AM	TIME OUT 10:58 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.



temperature (F)	No Data
observed flow (gpm)	110
required flow (gpm)	225
volume (gal)	108,281
area (sq ft)	2,625
occupancy	131

36K075 Equipment - Filter Pressure

POINTS
NA

Compliance Date not Specified
Not In Compliance
Violation Reference - CCR 24 - 3125B2

Inspector Comments: Differential pressure between the influent and effluent gauges observed greater than 15 psi. Provide backwashing.

Violation Description: Differential pressure of influent and effluent pressure gauges shall not exceed 15 psi. Backwash system and/or clean filter grids.

36K102 Safety - Safety Signs

POINTS
NA

Compliance Date not Specified
Not In Compliance
Violation Reference - CCR 24 - 3119B

Inspector Comments: Provide safety sign indicating that "Persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter pool water". Observed missing.

Violation Description: Safety signs are required to be conspicuously posted and maintained as to be legible: "Warning, No Lifeguard On Duty", "Occupant Load", diagrammatic illustrations of artificial respiration procedures, emergency telephone numbers (ambulance, fire, and police or sheriff's department), warning sign for spa containing "Caution" language, "Emergency Shut-off Switch" for spa. "No Diving Allowed" for shallow pools, "Danger: Gaseous Oxidizer Chlorine" for gas chlorinators, "No Use Of Pool Allowed After Dark" for pools without a light fixture.

36K115 Skimmers - Weir

POINTS
NA

Compliance Date not Specified
Not In Compliance
Violation Reference - CCR 24 - 3134

Inspector Comments: Observed weirs and floating assembly missing from skimmer. Provide weir and floating assembly as needed.

Violation Description: Skimmer(s) shall have a weir which automatically adjusts to variations of the water level less than 4 inches.

36K127 Water Quality - Cyanurates

POINTS
NA

Compliance Date not Specified
Not In Compliance
Violation Reference - CCR - 65529(a)

Inspector Comments: Cyanuric acid observed greater than 100ppm. Maintain the cyanuric acid at/below 100ppm.

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME TRINITY CHILDREN & FAMILY	DATE 4/23/2013	SIGNATURE
LOCATION 10776 N FREMONT AV, YUCAIPA, CA 92399		REHS Antonio Fields

Influent pressure 1: 30 psi
Influent pressure 2: 27 psi
Effluent pressure: 0 psi
Cyanuric acid: > 100 ppm

Violations reviewed with pool operator.

Photo Attachments:

No Photo Attachments