



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dehs




(800) 442-2283

FACILITY NAME COUNTRY CLUB TERRACE APTS				DATE 4/24/2013	SIGNATURE
LOCATION 7430 CAMINO DEL CIELO, YUCCA VALLEY, CA 92286				REINSPECTION DATE 10/24/2013	PERMIT EXPIRATION 12/31/2013
MAILING ADDRESS PO BOX 20, YUCCA VALLEY CA 92286				REHS Dior Porter	
FA # FA0007310	PR # PR0014649	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 2:11 PM	TIME OUT 2:50 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	66
volume (gal)	23,936
area (sq ft)	800
occupancy	40

36K083 Equipment - Flow Meter functioning

POINTS NA	Compliance Date not Specified	Inspector Comments: Observed inoperable flow meter. Repair.
	Not In Compliance	
	Violation Reference - CCR	

Violation Description: The flow meter must be maintained functional and in good repair.

36K126 Water Quality - Cleanliness - Pool Surface

POINTS NA	Compliance Date not Specified	Inspector Comments: Observed small amount of dirt/debris inside of the pool. Clean and maintain.
	Not In Compliance	
	Violation Reference - CCR - 65533	

Violation Description: Floating scum, sputum, or debris are not allowed to accumulate in the pool. Skimmers shall be maintained and operated to remove such material continuously.

Overall Inspection Comments

Observed all gates to pool locked with hanging "master locks". Resident provided access to pool. Ensure one gate is designated to have a keyless egress and mark gate with "emergency exit" sign, UNLESS structure was built prior July 1st, 1994. Thank you!

Photo Attachments:

No Photo Attachments