



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>LA FITNESS</b>				DATE <b>5/2/2013</b>	SIGNATURE	
LOCATION <b>14485 PIPELINE AV, CHINO HILLS, CA 91709</b>				REINSPECTION DATE <b>11/02/2013</b>	PERMIT EXPIRATION <b>9/30/2013</b>	
MAILING ADDRESS <b>PO BOX 52110, IRVINE CA 92619</b>				REHS <b>Tin Nguyen</b>		
FA # <b>FA0000838</b>	PR # <b>PR0015845</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Pool	
TIME IN <b>9:57 AM</b>	TIME OUT <b>10:17 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine	
					RESULT: 03 - Corrective Action / No Follow up Required	
					ACTION: 01 - No Further Action Required	

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**98**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	60
required flow (gpm)	151
volume (gal)	54,400
area (sq ft)	1,849
occupancy	92

**36K414 Water Quality - Non-Critical - pH High/Low**

**POINTS**  
**2**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - CCR - 65529

Inspector Comments: Observed pH level between 7.0 and 7.2. Ensure pH level is maintained between 7.2 - 8.0.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**Overall Inspection Comments**

pH: 7.0  
 Chlorine: 9.0 ppm  
 CYA: 0 ppm  
 Flow rate: 60 gpm  
 Required flow rate: 151 gpm

**Photo Attachments:**  
 No Photo Attachments