



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME IRIS GARDEN				DATE 5/2/2013	SIGNATURE
LOCATION 12253 TULIP LN, YUCAIPA, CA 92399				REINSPECTION DATE 11/02/2013	PERMIT EXPIRATION 7/31/2013
MAILING ADDRESS 195 N EUCLID AV STE 100, UPLAND CA 91786				REHS Antonio Fields	
FA # FA0016374	PR # PR0021805	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: SPA
TIME IN 11:29 AM	TIME OUT 12:11 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	92.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	65,000
area (sq ft)	1,500
occupancy	No Data

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Cyanuric acid observed above 100 ppm. Ensure the cyanuric acid does not exceed 100ppm.

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Range on the flow meter observed no low enough to read the flow rate of the spa. Provide an adequate flow meter.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow.

36K458 Maintenance - Test Kit/Daily Records

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65523, 65529

Inspector Comments: Daily record observed missing. Provide a daily log of chemical maintenance within the spa.

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

Overall Inspection Comments

Ensure signs are updated to current pool/spa regulations.

Influent pressure: 27 psi
Effluent pressure: 5 psi
Cyanuric acid: < 30 ppm

Code to the gate and combination lock attached to the equipment room distributed to the County of San Bernardino observed invalid. Provide updated codes.

Operator unavailable for signature.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME IRIS GARDEN	DATE 5/2/2013	SIGNATURE
LOCATION 12253 TULIP LN, YUCAIPA, CA 92399		REHS Antonio Fields

Photo Attachments:

No Photo Attachments