



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN EXPRESS				DATE 5/7/2013	SIGNATURE
LOCATION 9589 MILLIKEN AV, RANCHO CUCAMONGA, CA 91730				REINSPECTION DATE 11/07/2013	PERMIT EXPIRATION 3/31/2014
MAILING ADDRESS 9589 MILLIKEN AV, RANCHO CUCAMONGA CA 91730				REHS Sumedha Singh	
FA # FA0014414	PR # PR0019075	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 1:56 PM	TIME OUT 2:30 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

96

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	90
required flow (gpm)	49
volume (gal)	17,645
area (sq ft)	594
occupancy	29

36K402 Water Quality - Critical - Lack of Disinfectant

CRITICAL

POINTS
4

Compliance Date: Not Specified
Complied on 5/7/2013
Violation Reference - CCR - 65529

Inspector Comments: Observed liquid chlorine being used with a chlorine level of .5 ppm. Adjusted on site to 2.0 ppm. Violation corrected on site.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN EXPRESS	DATE 5/7/2013	SIGNATURE
LOCATION 9589 MILLIKEN AV, RANCHO CUCAMONGA, CA 91730		REHS Sumedha Singh

REQUIRED SIGNS FOR POOLS

All signs must be posted in a location visible to all pool users.

1. "WARNING - NO LIFEGUARD ON DUTY"

- Required at all spas where lifeguard service is not provided.
- Letters must be at least 4" high.
- Sign must be located in plain view of persons entering the spa area.
- The sign also shall state in letters at least 1 inch (25 mm) high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."

2. ARTIFICIAL RESPIRATION AND CPR

- Sign must have illustrated diagrams with artificial respiration and CPR procedures.
- Text at least ¼ inch high
- Sign must be posted within the spa enclosure and be clearly visible.

3. EMERGENCY TELEPHONE NUMBERS

- Shall have "911" number.
- Shall include the number of the nearest emergency services.
- Shall include the name and street address of the pool facility shall be posted.
- Letters shall be not less than 4 inches (102 mm) high.

4. OCCUPANCY LOAD

- Must have clearly legible letter/numerals not less than 4 inches (102 mm) high.
- Shall indicate the maximum number of pool users permitted for each pool.
- The pool user capacity for all pools (except spas) shall be based on one pool user for every 20 square feet (1.858 m²) of pool water surface area.

5. "NO DIVING"

- Signs shall be posted in conspicuous places and shall state, "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Letters shall be not less than 4 inches (102 mm) high.

6. "NO USE OF POOL ALLOWED AFTER DARK"

- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s).
- Letters shall be not less than 4 inches (102 mm) high.

7. "KEEP CLOSED"

- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area.
- Letters shall be not less than 4 inches (102 mm) high.

8. "Diarrhea"

- A sign in a language or diagram that states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- Letters shall be at least 1 inch (25 mm) high.
- It shall be posted in a location visible to entrance area.

-Ensure all pump equipment has directional flow of water.

Photo Attachments:

No Photo Attachments