



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME THUNDERBIRD MOBILE HOMES				DATE 5/9/2013	SIGNATURE <i>Thelia Ramos</i>
LOCATION 760 E 9TH ST, SAN BERNARDINO, CA 92410				REINSPECTION DATE 11/09/2013	PERMIT EXPIRATION 6/30/2013
MAILING ADDRESS 760 E 9TH ST, SAN BERNARDINO, CA 92410				REHS John Babalola	
FA # FA0008815	PR # PR0014598	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: None
TIME IN 10:11 AM	TIME OUT 11:17 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	100
required flow (gpm)	103
volume (gal)	37,000
area (sq ft)	1,100
occupancy	55

36K406 Water Quality - Critical - pH High/Low

CRITICAL

POINTS 4	Compliance Date: Not Specified	Inspector Comments: The pH level is observed above 8.0.
	Not In Compliance	Note: Correction is being made.
	Violation Reference - CCR - 65529	

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K428 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Warning sign about persons with active diarrhea and persons with diarrhea within 14 days is not observed. Provide the sign. The water flow direction is not observed on the pipes. Keep gate closed sign is not observed. Provide the signs.
	Not In Compliance	
	Violation Reference - CCR - 3120B, 65539	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K466 Structure - Pool Shell

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Yellow algae buildup observed on the pool shell.
	Not In Compliance	
	Violation Reference - CCR - 3108B	

Violation Description: The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent.

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME THUNDERBIRD MOBILE HOMES	DATE 5/9/2013	SIGNATURE <i>Thelia Ramos</i>
LOCATION 760 E 9TH ST, SAN BERNARDINO, CA 92410		REHS John Babalola

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments