



County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>SIERRA VILLAGE APARTMENTS</b>					DATE 5/10/2013	SIGNATURE <i>Roanna Reynolds</i>	
LOCATION 2443 WINDSOR DR, SAN BERNARDINO, CA 92404					REINSPECTION DATE 5/24/2013	PERMIT EXPIRATION 4/30/2013	
MAILING ADDRESS 8504 FIRESTONE BLVD STE 161, DOWNEY CA 90241					REHS Chaz Harrison		
FA # FA0008805	PR # PR0015711	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool		
TIME IN 3:29 PM	TIME OUT 4:32 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine		
					RESULT: 05 - Corrective Action / Follow up Required		
					ACTION: 14 - Permit Suspd / Facility Closed fencing iss		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**80**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K995 Permit - Suspension**

**⚠ CRITICAL ⚠**

**POINTS**  
**NA**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC

**Inspector Comments:**

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K991 Permit Investigation**

**POINTS**  
**NA**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC

**Inspector Comments:** Observed expired permit. Ensure to obtain a current health permit within three business days.

**Violation Description:** Obtain a valid health permit within 3 days or as specified to avoid facility closure and/or other possible legal action.

**36K402 Water Quality - Critical - Lack of Disinfectant**

**⚠ CRITICAL ⚠**

**POINTS**  
**4**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed no chlorine detected at time of inspection; Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K436 Enclosure - Critical - Enclosure Drowning Hazard**

**⚠ CRITICAL ⚠**

**POINTS**  
**4**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR 24 - 3119B

**Inspector Comments:** Observed sliding windows and doors for the recreational room without locks. Recreational doors and windows lead directly to pool. Doors, and windows leading to pool area should be locked at all times. Ensure to install locks on windows and doors to prevent entry into pool.

**Violation Description:** The pool shall be enclosed by one or a combination of the following: a fence; portion of a building; wall; or other approved durable enclosure. Doors, windows gates of living units or associated private premises shall not be permitted as part of the pool enclosure. The enclosure shall have a minimum effective perpendicular height of 5 feet. Openings, holes or gaps in the enclosure, doors and/or gates shall not allow the passage of a 4-inch diameter sphere. The enclosure shall be constructed over a hard and permanent material equivalent to concrete. The enclosure shall be designed and constructed so that it cannot be readily climbed by small children.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>SIERRA VILLAGE APARTMENTS</b>		DATE 5/10/2013	SIGNATURE <i>Koanna S. Reynolds</i>
LOCATION 2443 WINDSOR DR, SAN BERNARDINO, CA 92404		REHS Chaz Harrison	

**36K438 Enclosure - Critical - Gates Drowning Hazard** **⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed north eastern gate not self latching. Ensure all gates are self latching. Test the gate by opening to approximately 18 inches and allow closing. If one or more of the pool gates is not self-closing and self-latching, or is in disrepair - CLOSE the pool and/or secure the problem gate(s) with a zip tie or a chain and lock until gate(s) is repaired.
	Not In Compliance Violation Reference - HSC - 3119B	

**Violation Description:** Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

**36K428 Safety - Safety Signs**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Ensure to obtain safety signs. No safety signs observed. Pool and spa signs shall be in plain view from all parts of the pool/spa enclosure and be maintained in good repair. Letters shall be a minimum of 4 inches for easy readability. The following signs shall be kept on site in the pool and spa area: <ul style="list-style-type: none"> <li>• "911" Emergency number</li> <li>• Artificial Respiration Procedures rescue breathing)</li> <li>• Danger: Gaseous Oxidizer Chlorine (required for pools with chlorine gas with the hazard ID symbol posted on the exterior door where chlorine gas is located)</li> <li>• No Diving Allowed (if less than 6 foot depth)</li> <li>• No Life Guard On Duty</li> <li>• No Use of Pool After Dark (for pools without sufficient lighting or (missing light fixture)</li> <li>• Occupant capacity (not required for wading pool)</li> </ul>
	Not In Compliance Violation Reference - CCR - 3120B, 65539	

Ensure to install the following signs below on the entry gate.

Keep closed. A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."

3120B.11 Diarrhea. A sign in letters at least 1 inch (25 mm) high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

(800) 442-2283

FACILITY NAME <b>SIERRA VILLAGE APARTMENTS</b>		DATE <b>5/10/2013</b>	SIGNATURE <i>Koanna S. Reynolds</i>
LOCATION <b>2443 WINDSOR DR, SAN BERNARDINO, CA 92404</b>		REHS <b>Chaz Harrison</b>	

**36K430 Safety - Equipment/First Aid Kit**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no test kit. Ensure to obtain a test kit. Taylor k-2009(recommended).  Observed no first aid kit. Ensure to obtain a first aid kit.  Observed no life ring. Ensure to obtain a life ring. All swimming pools are required to provide a life ring with an outside diameter of 17 inches and a rope (at least 3/16 inches in diameter) attached that is long enough to span the widest part of the pool.
	Not In Compliance Violation Reference - CCR - 65539	

**Violation Description:** Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

**36K466 Structure - Pool Shell**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed pool shell chipping. Pool and spa shell shall be in good condition, clean and well maintained. The pool shell must be white in color; free of any projections and designs. Spa shell may have a light pastel color. If plaster is significantly worn, chipped, etc., Ensure to replaster.
	Not In Compliance Violation Reference - CCR - 3108B	

**Violation Description:** The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent.

**36K482 Restrooms - Toilet Facilities - Showers**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed toilet not properly working. Ensure restroom facilities are fully functioning.  Restrooms shall be made available for use by residents. A separate Male and Female restroom is required. Restrooms shall be kept clean, stocked and in good repair. Restrooms shall have hot and cold water, soap and paper towel dispensers (or hand dryer) and proper lighting and ventilation.
	Not In Compliance Violation Reference - CCR - 65535, 65551, 3117B	

**Violation Description:** Toilets, urinals, showers, wash basins and other plumbing fixtures shall be maintained in a clean condition, and in good repair. For shower, toilet and dressing facilities, the walls, partitions, doors, lockers and similar surfaces which require periodic cleaning shall be maintained smooth and finished so as to facilitate- cleaning. Showers shall be provided with soap in soap dispensers or containers. For toilet facilities, handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues shall be provided in permanently installed dispensing devices.

One guarded jet drinking fountain shall be provided for the first 250 bathers and an additional fountain shall be provided for each additional 200 bathers or fraction thereof.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments