



County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

(800) 442-2283

FACILITY NAME <b>RACQUET CLUB CONDO</b>					DATE <b>5/10/2013</b>	SIGNATURE	
LOCATION <b>1180 W PHILADELPHIA, ONTARIO, CA 91761</b>					REINSPECTION DATE <b>11/10/2013</b>	PERMIT EXPIRATION <b>6/30/2013</b>	
MAILING ADDRESS <b>12345 MOUNTAIN AVE SUITE N239, CHINO CA 91710</b>					REHS <b>Hanan Megalla</b>		
FA # <b>FA0008421</b>	PR # <b>PR0014567</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: south wading pool		
TIME IN <b>7:55 AM</b>	TIME OUT <b>8:13 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**90**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K402 Water Quality - Critical - Lack of Disinfectant**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	Inspector Comments: Measured low concentration of free chlorine (0.5 ppm).
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	Inspector Comments: Repair or replace the inoperable flow meter.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow.

**36K460 Skimmers - Requirements**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	Inspector Comments: Provide the missing float assembly for wading pool skimmer.
	Not In Compliance	
	Violation Reference - CCR - 65533, 3136B	

**Violation Description:** Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**36K466 Structure - Pool Shell**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	Inspector Comments: Repair the corroded wading pool shell .
	Not In Compliance	
	Violation Reference - CCR - 3108B	

**Violation Description:** The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent.

**Overall Inspection Comments**

A copy of section 3120 B Required Signs sent to the management company.

**Photo Attachments:**

No Photo Attachments