



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>LA TERRAZA APARTMENTS</b>					DATE <b>5/10/2013</b>	SIGNATURE	
LOCATION <b>551 E RIVERSIDE DR, ONTARIO, CA 91761</b>					REINSPECTION DATE <b>11/10/2013</b>	PERMIT EXPIRATION <b>11/30/2013</b>	
MAILING ADDRESS <b>2566 OVERLAND AV UNIT 700, LOS ANGELES CA 90064</b>					REHS <b>Hanan Megalla</b>		
FA # <b>FA0005633</b>	PR # <b>PR0014118</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Pool		
TIME IN <b>1:39 PM</b>	TIME OUT <b>1:59 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine		
					RESULT: 03 - Corrective Action / No Follow up Required		
					ACTION: 01 - No Further Action Required		

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**98**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K460 Skimmers - Requirements**

POINTS  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65533, 3136B

Inspector Comments: Provide the missing weir gate for one of pool skimmers.

**Violation Description:** Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**Overall Inspection Comments**

Section 3120 B Required Signs Handout given to management on site.

**Photo Attachments:**

No Photo Attachments