



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

| | | | | | |
|---|-----------------------------|--------------------------------|------------------------------|--|--|
| FACILITY NAME HYATT PLACE | | | | DATE 5/10/2013 | SIGNATURE |
| LOCATION 4760 E MILLS CR, ONTARIO, CA 91764 | | | | REINSPECTION DATE 11/10/2013 | PERMIT EXPIRATION 8/31/2013 |
| MAILING ADDRESS 42 CORPORATE PARK STE 200, IRVINE CA 92606-3104 | | | | REHS Anies Kondoker | |
| FA # FA0000700 | PR # PR0015960 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: pool |
| TIME IN 10:48 AM | TIME OUT 11:31 AM | CONTACT Not Captured | | | SERVICE: 001 - Inspection - Routine |
| | | | | | RESULT: 03 - Corrective Action / No Follow up Required |
| | | | | | ACTION: 01 - No Further Action Required |

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | No Data |

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

| | | |
|---------------------------|---|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Relocate the sight glass to the line between filter and separation tank. |
| | Not In Compliance | |
| | Violation Reference - HSC - 3120B, 3132B, 3141B | |

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

36K448 Equipment - Flow Meter

| | | |
|---------------------------|-----------------------------------|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Repair/replace non-operating flow meter. |
| | Not In Compliance | |
| | Violation Reference - CCR - 3125B | |

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow.

36K460 Skimmers - Requirements

| | | |
|---------------------------|--|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Provide weir gate to north skimmer. |
| | Not In Compliance | |
| | Violation Reference - CCR - 65533, 3136B | |

Violation Description: Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

Overall Inspection Comments

pH = 7.2
Free chlorine = 6 ppm

Photo Attachments:
No Photo Attachments