



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME EL SUPER				DATE 5/13/2013	SIGNATURE	
LOCATION 16950 FOOTHILL BL, FONTANA, CA 92335				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2013	
MAILING ADDRESS <input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT 16950 FOOTHILL BL, FONTANA, CA 92335				REHS Sierra Clayborn		
FA # FA0005716	PR # PR0003258	SR # Not Specified	CO # Not Specified	PE 1611	PROGRAM IDENTIFIER: Tortilleria	
TIME IN 1:40 PM	TIME OUT 1:50 PM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection	
				RESULT: 03 - Corrective Action / No Follow up Required		
				ACTION: 15 - Permit Reinstated / Facility Re-opened		

RETAIL FOOD PROTECTION - FOOD HANDLING PL (500-2499 SQFT)

16K021 Hot and cold water available

⚠ CRITICAL ⚠

Compliance Date: Not Specified
Not In Compliance

Inspector Comments: During routine inspection, observed no hot water available in tortilleria. Highest temperature recorded was 78 F.

Violation Reference - HSC - 113953(c), 114099.2(b)

Violation Description: An adequate, protected, pressurized, potable supply of hot water and cold water shall be provided at all times. (113953(c), 114099.2(b) 114101(a), 114189, 114192, 114192.1, 114195)

16K054 Permit Suspension

⚠ CRITICAL ⚠

Compliance Date: Not Specified
Not In Compliance

Inspector Comments: Facility was temporarily closed for lack of hot water.

Violation Reference - HSC - 114409, 114405

Violation Description: If an imminent health hazard is found, an enforcement officer may temporarily suspend the permit and order the food facility immediately closed. (114409, 114405)

Overall Inspection Comments

Measured water temperature at 3 compartment sink and hand sink in excess of 120 F.

Re-opened facility.

Photo Attachments:
No Photo Attachments