



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME CALIFORNIA INN					DATE 5/14/2013	SIGNATURE	
LOCATION 1431 E MAIN ST, BARSTOW, CA 92311					REINSPECTION DATE 11/14/2013	PERMIT EXPIRATION 5/31/2013	
MAILING ADDRESS 1431 E MAIN ST, BARSTOW, CA 92311					REHS Kathy Taylor		
FA # FA0008643	PR # PR0015697	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool SERVICE: 001 - Inspection - Routine		
TIME IN 8:45 AM	TIME OUT 9:35 AM	CONTACT Not Captured			RESULT: 03 - Corrective Action / No Follow up Required ACTION: 01 - No Further Action Required		

RECREATIONAL HEALTH - PUBLIC POOL/SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

88

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	70.0
observed flow (gpm)	70
required flow (gpm)	95
volume (gal)	30,000
area (sq ft)	800
occupancy	40

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Pool found with no measurable chlorine residual which results in pool closure. Maintenance man was able to add chlorine at inspection time so pool is permitted to remain open. Check chlorine level each morning prior to opening pool to ensure at least 1.5 ppm of chlorine is present.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K430 Safety - Equipment/First Aid Kit

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65539

Inspector Comments: Provide hook on 12' pole for rescue purposes. Pole in pool area without hook. Permanently attach hook to pole so it may not be used with brush.

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 3120B, 3132B, 3141B

Inspector Comments: Ensure pump and filtration equipment is ON at all times pool is open for use. Pool opens at 7:00 am and pump found off. This also is contributing to the low chlorine level due to the fact that there is no continuous chlorination of pool due to pump off.

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Minimum required flow for this pool is 95 gpm but flowmeter only reading 70 gpm. Please check all valves, ensure filter is clean and check all skimmers for possible obstructions to flow. Ensure a minimum flow rate of 95 is reflected on flowmeter.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME CALIFORNIA INN	DATE 5/14/2013	SIGNATURE
LOCATION 1431 E MAIN ST, BARSTOW, CA 92311	REHS Kathy Taylor	

36K460 Skimmers - Requirements

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Provide wier gates at each skimmer (missing). This is the plastic flap that is attached at mouth of skimmer to allow floating debris to enter skimmer but not return out to pool.
	Not In Compliance	
	Violation Reference - CCR - 65533, 3136B	

Violation Description: Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

Overall Inspection Comments

pH found at upper legal limit of 8.0. Maintenance man to add pH reducer after chlorine addition. Keep pool closed during chemical dispensen.

New signs are required for next year. Flyer left. In the meantime, it is suggested that you post the diarrhea warning sign (available at pool shop or online).

Provide directional arrows on piping showing direction of water flow.

Valve skimmer and main drain separately. Currently one valve for adjusting flow. The desirable ratio is to have 75% of the flow coming from the skimmers and only 25% from main drain. This will also lower any suction hazard from main drains.

Pool water clean/clear. Pool fencing and gate are within code. The pool filtration area is clean and neat and all equipment is easily accessible.

Keep daily records of pH and chlorine.

Thank you

Photo Attachments:

No Photo Attachments