



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME RAINTREE GARDENS				DATE 5/14/2013	SIGNATURE
LOCATION 18125 BELLFLOWER, ADELANTO, CA 92301				REINSPECTION DATE 11/14/2013	PERMIT EXPIRATION 5/31/2013
MAILING ADDRESS 2667 N MOOREPARK RD UNIT 203, THOUSAND OAKS CA 91360				REHS Kathy Taylor	
FA # FA0008631	PR # PR0013611	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 12:40 PM	TIME OUT 1:15 PM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	78
volume (gal)	28,000
area (sq ft)	936
occupancy	46

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Prior to opening pool, ensure cyanuric acid level is below 100 ppm; found over 100 ppm today. To lower cyanuric acid, drain a little water out and add fresh water.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Repair stuck flowmeter and ensure the minimum flow is met for this pool. Unable to verify flow.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow.

36K460 Skimmers - Requirements

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65533, 3136B

Inspector Comments: Unable to remove basket from one skimmer (nearest office). Please check and ensure the skimmer has an equalizer line valve and a float assembly.

Violation Description: Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME RAINTREE GARDENS	DATE 5/14/2013	SIGNATURE
LOCATION 18125 BELLFLOWER, ADELANTO, CA 92301		REHS Kathy Taylor

Flyer left for new signs that are required for next pool season (2014). In the meantime, it is suggested you post the "Keep Closed" sign on the exterior of each gate and the diarrhea warning sign (to be easily visible to persons entering pool area at gate).

Minimum flow rate for this pool is 78 gpm; please correct stuck float in chamber of flowmeter and ensure at least 78 gpm are recirculated.

Provide directional arrows on piping showing direction of water flow.

Keep accurate records of pH and chlorine daily.

OK to open pool when ready; currently not open yet.

Thank you

Photo Attachments:
No Photo Attachments