



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**


(800) 442-2283

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>DEER PARK RESORT</b>				DATE 5/14/2013	SIGNATURE <i>see upper pool 003 5/14/13</i>
LOCATION 1924 GLEN HELEN RD, DEVORE, CA 92407				REINSPECTION DATE 10/14/2013	PERMIT EXPIRATION 12/31/2013
MAILING ADDRESS 1770 N ARROWHEAD AV, SAN BERNARDINO CA 92405				REHS <b>Dior Porter</b>	
FA # FA0006742	PR # PR0015777	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Lower Pool
TIME IN 9:41 AM	TIME OUT 10:34 AM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	77
volume (gal)	28,000
area (sq ft)	364
occupancy	18

**36K994 Reinspection**

**POINTS**  
**NA**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - HSC

**Inspector Comments:** Upon joint re-inspection with Leilah K. observed peeling/chipped pool shell. Re-plaster/repaint to ensure pool shell is smooth and durable, as well as non abrasive prior to May 2014 unless otherwise deemed necessary by this division.

Observed bricks beneath coping. Provide permanent solution for support that is safe and does not allow for any gaps or protrusions. Ensure construction is flush to the pool wall.

Observed rubber hose being used as part of the return line. Hose to be replaced with durable hard line of approved material once hose is no longer functional.

**Violation Description:** Reinspection conducted at this time to determine compliance from prior inspection.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments