



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME BEST WESTERN BIG BEAR CHATEAU				DATE 5/14/2013	SIGNATURE
LOCATION 42200 MOONRIDGE RD, BIG BEAR LAKE, CA 92315				REINSPECTION DATE 11/14/2013	PERMIT EXPIRATION 11/30/2013
MAILING ADDRESS PO BOX 1814, BIG BEAR LAKE CA 92315				REHS Cecilia Jones	
FA # FA0005560	PR # PR0015803	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: spa
TIME IN 10:31 AM	TIME OUT 10:58 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
				RESULT: 03 - Corrective Action / No Follow up Required	
				ACTION: 01 - No Further Action Required	

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

90

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	60.0
observed flow (gpm)	0
required flow (gpm)	25
volume (gal)	750
area (sq ft)	50
occupancy	5

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed chlorine level at 0 ppm. Maintain between 1.5 and 10 ppm.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K406 Water Quality - Critical - pH High/Low

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed pH exceeding 8.0. Maintain between 7.2 and 8.0

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Observed flow meter stuck. Repair or replace. Ensure that recirculating system is operating at 25 GPM.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow.

Overall Inspection Comments

Spa is closed until Memorial Day.
Ensure that all violations are corrected prior to opening spa and pool.

Photo Attachments:
No Photo Attachments