



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME DAYS INN SOUTH AT LENWOOD				DATE 5/15/2013	SIGNATURE
LOCATION 2551 COMMERCE PKWY, BARSTOW, CA 92311				REINSPECTION DATE 5/29/2013	PERMIT EXPIRATION 9/30/2013
MAILING ADDRESS 2551 COMMERCE PKWY, BARSTOW CA 92311				REHS Kathy Taylor	
FA # FA0002940	PR # PR0013945	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Spa SERVICE: 001 - Inspection - Routine
TIME IN 10:40 AM	TIME OUT 11:20 AM	CONTACT Not Captured			RESULT: 05 - Corrective Action / Follow up Required ACTION: 13 - Permit Suspended / Facility Closed

RECREATIONAL HEALTH - PUBLIC POOL/SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

80

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	90.0
observed flow (gpm)	No Data
required flow (gpm)	27
volume (gal)	794
area (sq ft)	48
occupancy	5

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Lower chlorine level to the 1.5 ppm - 10 ppm range. Pink color in testing chamber bleaching out indicating a VERY high chlorine level, in excess of 50 ppm. Spa Closed.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K406 Water Quality - Critical - pH High/Low

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Adjust pH so it is 7.2-8.0. Observed pH at 7.0 which is too acidic for bathers.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K464 Structure - Critical - Suction Outlets

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3136B, 3137B

Inspector Comments: Replace missing drain cover in spa; observed one missing. Ensure cover is VGBA compliant.

Violation Description: All suction outlets shall be equipped with suction fittings that meet the ASME/ANSI A112.19.8 performance standard. If used, a skimmer equalizer suction outlet located on the pool wall shall be connected to at least two suction grate assemblies and located at least 3 feet apart in any dimension between the drains. Suction fittings shall be secure and maintained in good repair.

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Lower cyanuric acid level in spa by draining out a little water and adding fresh; observed in excess of 100 ppm today.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME DAYS INN SOUTH AT LENWOOD	DATE 5/15/2013	SIGNATURE
LOCATION 2551 COMMERCE PKWY, BARSTOW, CA 92311	REHS Kathy Taylor	

36K428 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Provide new spa signs (emergency cut off switch, occupancy, etc.) Observed faced.
	Violation Reference - CCR 24 - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Repair flowmeter so it accurately reflects the minimum turnover rate for spa. The turnover rate for this spa is 27 gpm but unable to determine today due to stuck flowmeter. Please repair.
	Violation Reference - CCR - 3125B	

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K466 Structure - Pool Shell

POINTS 2	Compliance Date: Not Specified Not In Compliance	Inspector Comments: Spa shell in need of refinishing. The blue color and deteriorating shell is probably due to your low pH level which is leaching out copper from lines (heater) and deteriorating your spa shell. Replaster prior to next pool season.
	Violation Reference - CCR - 3108B	

Violation Description: The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.

Overall Inspection Comments

Spa closed due to excess chlorine level, pH too low and missing suction cover on spa shell. Please correct all three issues prior to calling for reinspection.

Call for reopening inspecton at 1-800-442-2283.

Thank you

Photo Attachments:

No Photo Attachments