



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME <b>FREMONT HEIGHTS MHP</b>					DATE <b>5/15/2013</b>	SIGNATURE	
LOCATION <b>12151 FREMONT ST, YUCAIPA, CA 92399</b>					REINSPECTION DATE <b>5/29/2013</b>	PERMIT EXPIRATION <b>12/31/2013</b>	
MAILING ADDRESS <b>PO BOX 91463, LONG BEACH CA 90809</b>					REHS <b>Antonio Fields</b>		
FA # <b>FA0007181</b>	PR # <b>PR0014711</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Spa SERVICE: 001 - Inspection - Routine		
TIME IN <b>3:21 PM</b>	TIME OUT <b>3:55 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 05 - Corrective Action / Follow up Required ACTION: 13 - Permit Suspended / Facility Closed		




**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**92**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	103.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K995 Permit - Suspension**

**⚠ CRITICAL ⚠**

**POINTS**  
**NA**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC

**Inspector Comments:** Permit suspended and spa closed due to high free chlorine and pH concentrations. Contact the County of San Bernardino at 800-442-2283 when ready to be reopened.

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K404 Water Quality - Critical - High Disinfectant Level**

**⚠ CRITICAL ⚠**

**POINTS**  
**4**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Chlorine concentration observed at 17 ppm. Maintain the free chlorine concentration between 1.5 - 10 ppm.

**Violation Description:** Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

**36K406 Water Quality - Critical - pH High/Low**

**⚠ CRITICAL ⚠**

**POINTS**  
**4**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Observed the pH above 8.0. Maintain the pH between 7.2 - 8.0.

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**Overall Inspection Comments**



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

**(800) 442-2283**

FACILITY NAME <b>FREMONT HEIGHTS MHP</b>	DATE <b>5/15/2013</b>	SIGNATURE
LOCATION <b>12151 FREMONT ST, YUCAIPA, CA 92399</b>	REHS <b>Antonio Fields</b>	

The following shall be posted:

- Maximum number of pool users permitted for each pool.
- “NO DIVING” at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, “WARNING: NO LIFEGUARD ON DUTY.” The sign also shall state in letters at least 1 inch high, “Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.”
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
- A warning sign for spa pools with “CAUTION” language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, “NO USE OF POOL ALLOWED AFTER DARK.”
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating , “KEEP CLOSED.”
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states , “CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.”

Closure notice posted do not remove or relocate.

Unable to get into the equipment room during the time of inspection.

**Photo Attachments:**

No Photo Attachments