



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME PARC CLAREMONT APARTMENTS				DATE 5/17/2013	SIGNATURE
LOCATION 1810 W ARROW ROUTE , UPLAND, CA 91786				REINSPECTION DATE 11/17/2013	PERMIT EXPIRATION 12/31/2013
MAILING ADDRESS 1810 W ARROW ROUTE , UPLAND, CA 91786				REHS Jose Rodriguez	
FA # FA0005524	PR # PR0014157	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 9:20 AM	TIME OUT 9:50 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required



RECREATIONAL HEALTH - PUBLIC POOL/SPA

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

96
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	90
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid levels greater than 100 ppm. Maintain between 30-50 ppm.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K482 Restrooms - Toilet Facilities - Showers - Drinking Fountain

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65535, 65551, 3117B

Inspector Comments: Keep toilet paper inside men's restroom. Observed missing.

Violation Description: Toilets, urinals, showers, wash basins and other plumbing fixtures shall be maintained in a clean condition, and in good repair. For shower, toilet and dressing facilities, the walls, partitions, doors, lockers and similar surfaces which require periodic cleaning shall be maintained smooth and finished so as to facilitate- cleaning. Showers shall be provided with soap in soap dispensers or containers. For toilet facilities, handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues shall be provided in permanently installed dispensing devices. Showers and lavatories shall be provided with hot and cold water faucets.

One guarded jet drinking fountain shall be provided for the first 250 bathers and an additional fountain shall be provided for each additional 200 bathers or fraction thereof.

Overall Inspection Comments

Flyer for new pool signs given.
Observed facility in compliance with new signs.

Photo Attachments:
No Photo Attachments