



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

**(800) 442-2283**

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>COTTAGE PARK HOA</b>				DATE <b>5/17/2013</b>	SIGNATURE
LOCATION <b>821 S MOUNTAIN, ONTARIO, CA 91761</b>				REINSPECTION DATE <b>11/17/2013</b>	PERMIT EXPIRATION <b>6/30/2013</b>
MAILING ADDRESS <b>9231 ARCHIBALD AV, RANCHO CUCAMONGA CA 91730</b>				REHS <b>Hanan Megalla</b>	
FA # <b>FA0008446</b>	PR # <b>PR0014544</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: spa
TIME IN <b>11:19 AM</b>	TIME OUT <b>11:37 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**94**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	81.0
observed flow (gpm)	No Data
required flow (gpm)	12
volume (gal)	735
area (sq ft)	28
occupancy	3

**36K414 Water Quality - Non-Critical - pH High/Low**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65529

**Inspector Comments:** Measured low pH @ 7.0 .

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**36K448 Equipment - Flow Meter**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 3125B

**Inspector Comments:** Repair or replace the inoperable flow meter for spa circulation.

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K460 Skimmers - Requirements**

**POINTS**  
**2**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - CCR - 65533, 3136B

**Inspector Comments:** Provide the missing weir gate and missing float assembly.

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**Overall Inspection Comments**

A copy of section 3120 B Required Signs sent to the management company.

**Photo Attachments:**

No Photo Attachments