



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME LEISURE HOME MHP				DATE 5/22/2013	SIGNATURE
LOCATION 600 E RIMROCK RD, BARSTOW, CA 92311				REINSPECTION DATE 11/22/2013	PERMIT EXPIRATION 8/31/2013
MAILING ADDRESS PO BOX 91463, LONG BEACH CA 90809-1463				REHS Kathy Taylor	
FA # FA0007054	PR # PR0014011	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 10:00 AM	TIME OUT 10:45 AM	CONTACT Not Captured			SERVICE: 001 - Inspection - Routine
					RESULT: 03 - Corrective Action / No Follow up Required
					ACTION: 01 - No Further Action Required

RECREATIONAL HEALTH - PUBLIC POOL/SPA


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

88

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	52
volume (gal)	25,000
area (sq ft)	360
occupancy	18

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Keep chlorine level at least 1.5 ppm to keep pool water clean and clear; found low today at 1.0 ppm.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K414 Water Quality - Non-Critical - pH High/Low

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Lower pH level to the 7.4-7.6 range; found high today at 8.0 or 8.2 but pool is voluntarily closed.

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K430 Safety - Equipment/First Aid Kit

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65539

Inspector Comments: Prior to opening, keep life ring with rope attached (long enough to span pool width) in pool area.

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Flowmeter reading about 40 gpm if working (unable to determine); minimum flow for this pool is 52 gpm; please check and repair.

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dehs

FACILITY NAME LEISURE HOME MHP	DATE 5/22/2013	SIGNATURE
LOCATION 600 E RIMROCK RD, BARSTOW, CA 92311	REHS Kathy Taylor	

36K470 Construction - Alteration - Submit Plans

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Prior to gate/fencing construction, contact DEHS Plan check at 1-800-442-2283. Plans are required for new fencing.
	Not In Compliance	
	Violation Reference - CCR - 3103B.1	

Violation Description: A person proposing to construct, renovate or alter a pool, ancillary facilities or equipment and appurtenances shall submit plans and specifications to DEHS for review and written approval prior to commencing construction and shall first be cleared by DEHS before substitution if not an exact duplicate of the units being changed or replaced.

Overall Inspection Comments

New sign requirements to go into effect next pool season (2014); flyer left outlining changes. Please call if you have questions.

Provide directional arrows on pool piping to show direction of water flow.

Thank you

Photo Attachments:

No Photo Attachments