



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**



(800) 442-2283

[www.sbcounty.gov/dehs](http://www.sbcounty.gov/dehs)

FACILITY NAME <b>MOUNTAIN SPRINGS</b>				DATE <b>5/22/2013</b>	SIGNATURE	
LOCATION <b>1413 SAN BERNARDINO RD, UPLAND, CA 91786</b>				REINSPECTION DATE <b>10/22/2013</b>	PERMIT EXPIRATION <b>6/30/2013</b>	
MAILING ADDRESS <b>1413 SAN BERNARDINO RD, UPLAND, CA 91786</b>				<input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT REHS <b>Shannon Johnson</b>		
FA # <b>FA0006123</b>	PR # <b>PR0014891</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: office pool	
TIME IN <b>2:30 PM</b>	TIME OUT <b>2:35 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 003 - Inspection - Follow Up Inspection	
					RESULT: 01 - Corrective Action Not Required	
					ACTION: 01 - No Further Action Required	

**RECREATIONAL HEALTH - PUBLIC POOL/SPA**

<b>Ideal</b>
<b>In Compliance</b>
<b>Not in Compliance</b>



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	75
volume (gal)	27,100
area (sq ft)	905
occupancy	45

**36K994 Reinspection**

<b>POINTS</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> The fence was repaired and there are no outstanding gaps under the bottom of the fence at this time.
<b>NA</b>	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Reinspection conducted at this time to determine compliance from prior inspection.

**Overall Inspection Comments**

Repair the recirculation system for this pool. Contact this department when all repairs have been made in order for re-opening to occur. This pool must remain closed until that time.

**Photo Attachments:**  
No Photo Attachments