



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dehs

(800) 442-2283

FACILITY NAME FRIENDLY HILLS M EST LLC				DATE 5/23/2013	SIGNATURE
LOCATION 2140 S MENTONE BL, MENTONE, CA 92359				REINSPECTION DATE 6/06/2013	PERMIT EXPIRATION 12/31/2013
MAILING ADDRESS 250 W FIRST ST 205, CLAREMONT CA 91711-4743				REHS Antonio Fields	
FA # FA0007184	PR # PR0014712	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: pool
TIME IN 3:00 PM	TIME OUT 3:17 PM	CONTACT Not Captured			SERVICE: 003 - Inspection - Follow Up Inspection
					RESULT: 05 - Corrective Action / Follow up Required
					ACTION: 13 - Permit Suspended / Facility Closed

RECREATIONAL HEALTH - PUBLIC POOL/SPA



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	150
volume (gal)	72,000
area (sq ft)	0
occupancy	45

36K995 Permit - Suspension



POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: Pool shall remain closed due to unsafe free chlorine levels.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K404 Water Quality - Critical - High Disinfectant Level



POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Free chlorine concentration observed above 30 ppm. Maintain free chlorine between 1.5-10ppm.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

Overall Inspection Comments

Closure notice shall remain posted. Follow-up needed.

Photo Attachments:

No Photo Attachments